

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Sedgwick	Fraction 1/4 NE 1/4 NW 1/4	Section number 29	Township number T 28 S R 1E	Range number E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 701 W. 55th South Wichita, Kansas			3. Owner of well: Harry Kissack R.R. or street: 701 W. 55th South City, state, zip code: Wichita, Kansas		
4. Locate with "X" in section below: 			Sketch map:		
5. Type and color of material			6. Bore hole dia. 11 in. Completion date 10-2-78 Well depth 50 ft.		
			7. ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary		
			8. Use: ☐ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☒ Lawn ☐ Oil field water ☐ Other		
			9. Casing: Material Styrene Height: Above or below Threaded ☐ Welded ☐ gl Surface 12 in. RMP ☒ PVC ☐ Weight 16 lbs./ft. Dia. 6 in. to 50 ft. depth Wall Thickness: inches or Dia. 6 in. to 50 ft. depth gage No. 200		
			10. Screen: Manufacturer's name Sunflower plastic Type styrene Dia. 6" Slot/gage .06 Length 20' Set between 30 ft. and 50 ft. ft. and 50 ft. Gravel pack? yes Size range of material 1/4-1/8"		
11. Static water level: 15 ft. below land surface Date 10-2-78 mo./day/yr.			12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
13. Water sample submitted: ____ Yes ____ No Date ____ mo./day/yr.			14. Well head completion: 12 capped ____ Pitless adapter ____ inches above grade		
15. Well grouted? yes 1-2 fine sand mix With: ____ Neat cement ____ Bentonite ☒ Concrete Depth: From 40" ft. to 14 ft.			16. Nearest source of possible contamination: ft. 400 Direction North Type Septic Well disinfected upon completion? ☒ Yes tank No		
17. Pump: ☒ Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. 67209 Address Signed M. Arnold Date 12-30-78 Authorized representative		
18. Elevation: Topography: ☐ Hill ☐ Slope ☐ Upland ☐ Valley			19. Remarks: Flat ground		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5