

1 LOCATION OF WATER WELL: Fraction SW 1/4 SE 1/4 Section 19 Township Number 28S Range Number 20E
County: Sedgwick
Distance and direction from nearest town or city street address of well if located within city?
1242 E. 55th S.

2 WATER WELL OWNER: Bill Rose
RR#, St. Address, Box #: 1111 N. Coach House Circle
City, State, ZIP Code: Wichita, KS 67235
Board of Agriculture, Division of Water Resources
Application Number:

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:
[Diagram showing a 36-section grid with 'X' in the SE corner of the SW 1/4 section]

4 DEPTH OF COMPLETED WELL: 100 ft. ELEVATION: 3120.1 ft.
Depth(s) Groundwater Encountered: 1 ft. 2. ft. 3. ft.
WELL'S STATIC WATER LEVEL: 14 ft. below land surface measured on mo/day/yr 3-20-01
Pump test data: Well water was ft. after hours pumping gpm
Est. Yield 12 gpm: Well water was ft. after hours pumping gpm
Bore Hole Diameter: 1 in. to 100 ft., and in. to ft.
WELL WATER TO BE USED AS:
1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well
Was a chemical/bacteriological sample submitted to Department? Yes No X If yes, mo/day/yr sample was submitted
Water Well Disinfected? Yes X No

5 TYPE OF BLANK CASING USED:
1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued X Clamped
2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded
Blank casing diameter in. to 20 ft. Dia. 2.40 in. to ft. Dia. in. to ft.
Casing height above land surface in. weight 240 lbs./ft. Wall thickness or gauge No. 100 psi
TYPE OF SCREEN OR PERFORATION MATERIAL:
1 Steel 3 Stainless steel 5 Fiberglass 7 PVC 10 Asbestos-cement
2 Brass 4 Galvanized steel 6 Concrete tile 8 RMP (SR) 11 Other (specify)
12 None used (open hole)
SCREEN OR PERFORATION OPENINGS ARE:
1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)
2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes
7 Torch cut 10 Other (specify)
SCREEN-PERFORATED INTERVALS: From 20 ft. to 80 ft. From ft. to ft.
From 14 ft. to 80 ft. From ft. to ft.
GRAVEL PACK INTERVALS: From 14 ft. to 80 ft. From ft. to ft.
From ft. to ft. From ft. to ft.

6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other
Grout Intervals: From 3 ft. to 14 ft. From ft. to ft. From ft. to ft.
What is the nearest source of possible contamination:
1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well
2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well
3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below)
13 Insecticide storage
Direction from well? North How many feet? 40

FROM TO LITHOLOGIC LOG FROM TO PLUGGING INTERVALS
0 2 top soil
2 12 clay
12 32 brown rock
32 100 grey shale

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 3-20-01 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 28 This Water Well Record was completed on (mo/day/yr) 3-20-01 under the business name of Weninger Drilling Inc. by (signature) Michelle Gorges

INSTRUCTIONS: Use typewriter or ball point pen. PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Bureau of Water, Topeka, Kansas 66620-0001. Telephone: 913-296-5545. Send one to WATER WELL OWNER and retain one for your records.