

1 LOCATION OF WATER WELL		Fraction	Section Number	Township Number	Range Number
County: Jedgwick		SW 1/4 SW 1/4 SE 1/4	11	T 28 S	R 2 E
Distance and direction from nearest town or city? 4N 2 1/2 W of Rose Hill			Street address of well if located within city? 13826 E. 39th St		
2 WATER WELL OWNER: STAN LAWERNCE					
RR#, St. Address, Box #: 16101 Hamlin					
City, State, ZIP Code: Wichita KS 67230					
Board of Agriculture, Division of Water Resources Application Number:					
3 DEPTH OF COMPLETED WELL: 105 ft. Bore Hole Diameter: 8 in. to 10.5 ft., and _____ in. to _____ ft.					
Well Water to be used as:					
1 Domestic		3 Feedlot	5 Public water supply	8 Air conditioning	11 Injection well
2 Irrigation		4 Industrial	6 Oil field water supply	9 Dewatering	12 Other (Specify below)
7 Lawn and garden only		10 Observation well			
Well's static water level: 63 ft. below land surface measured on 9 month 22 day 80 year					
Pump Test Data					
Est. Yield		gpm:	Well water was	ft. after	hours pumping
			Well water was	ft. after	hours pumping
4 TYPE OF BLANK CASING USED:					
1 Steel		3 RMP (SR)	5 Wrought iron	8 Concrete tile	Casing Joints: Glued ☒ Clamped _____
2 PVC		4 ABS	6 Asbestos-Cement	9 Other (specify below)	Welded _____
			7 Fiberglass		Threaded _____
Blank casing dia: 5 in. to _____ ft., Dia _____ in. to _____ ft., Dia _____ in. to _____ ft.					
Casing height above land surface: 12 in., weight _____ lbs./ft. Wall thickness or gauge No: 160 16					
TYPE OF SCREEN OR PERFORATION MATERIAL:					
1 Steel		3 Stainless steel	5 Fiberglass	8 RMP (SR)	10 Asbestos-cement
2 Brass		4 Galvanized steel	6 Concrete tile	9 ABS	11 Other (specify)
					12 None used (open hole)
Screen or Perforation Openings Are:					
1 Continuous slot		3 Mill slot	5 Gauzed wrapped	8 Saw cut	11 None (open hole)
2 Louvered shutter		4 Key punched	6 Wire wrapped	9 Drilled holes	
			7 Torch cut	10 Other (specify)	
Screen-Perforation Dia: 5 in. to 105 ft., Dia _____ in. to _____ ft., Dia _____ in. to _____ ft.					
Screen-Perforated Intervals: From 85 ft. to 105 ft., From _____ ft. to _____ ft., From _____ ft. to _____ ft.					
Gravel Pack Intervals: From 105 ft. to 25 ft., From _____ ft. to _____ ft., From _____ ft. to _____ ft.					
5 GROUT MATERIAL:					
1 Neat cement		2 Cement grout	3 Bentonite	4 Other	
Grouted Intervals: From 25 ft. to 4 ft., From _____ ft. to _____ ft., From _____ ft. to _____ ft.					
What is the nearest source of possible contamination:					
1 Septic tank		4 Cess pool	7 Sewage lagoon	10 Fuel storage	14 Abandoned water well
2 Sewer lines		5 Seepage pit	8 Feed yard	11 Fertilizer storage	15 Oil well/Gas well
3 Lateral lines		6 Pit privy	9 Livestock pens	12 Insecticide storage	16 Other (specify below)
				13 Watertight sewer lines	
Direction from well: N How many feet: 150 ? Water Well Disinfected? Yes ☒ No ☒					
Was a chemical/bacteriological sample submitted to Department? Yes _____ No ☒ If yes, date sample was submitted _____ month _____ day _____ year					
Pump Installed? Yes _____ No ☒ If yes, date sample was submitted _____ month _____ day _____ year					
If Yes: Pump Manufacturer's name _____ Model No. _____ HP _____ Volts _____					
Depth of Pump Intake _____ ft. Pumps Capacity rated at _____ gal./min.					
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other					
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on _____ month _____ day _____ year					
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 363					
This Water Well Record was completed on _____ month _____ day _____ year under the business name of Braddy Water Wells by (signature) Richard Braddy					
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		LITHOLOGIC LOG		LITHOLOGIC LOG	
		FROM	TO		
		0	5	Clay brown	
		5	50	Shale yellow	
		50	55	Shale Rusty Red	
		55	57	Shale light gray	
		57	62	Shale Rusty Red	
		62	80	Shale yellow	
		80	105	Shale gray	
ELEVATION: Slope					
Depth(s) Groundwater Encountered 1. 88 ft. 2. _____ ft. 3. _____ ft. 4. _____ ft. (Use a second sheet if needed)					

OFFICE USE ONLY

T

8

R

DEM

SEC.

11

SW 1/4 SW 1/4 SE 1/4