

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82g-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

County Sedgwick		Fraction Lot 2 SW 1/4 SW 1/4 1/4		Section number 22		Township number T 28 S R 2E E/W		Range number	
2. Distance and direction from nearest town or city: Hill, Kansas & 4 mi. W. N. side of road				3. Owner of well: Dan Carney & George Hall R.R. or street: P. O. Box 18422 City, state, zip code: Wichita, Kansas 67218					
4. Locate with "X" in section below:				Sketch map:		6. Bore hole dia. 11 in. Completion date 6-21-79 Well depth 60 ft.			
						7. ☒ Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored ___ Reverse rotary			
						8. Use: ☒ Domestic ___ Public supply ___ Industry ___ Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other			
5. Type and color of material				From To		9. Casing: Material Plas Height: Above or below Threaded ___ Welded ___ Surface 14 in. RMP ___ PVC ___ ☒ Night ___ lbs./ft. Dia. 8 in. to 60 ft. depth Wall Thickness: inches or Dia. ___ in. to ___ ft. depth gage No. 322			
						10. Screen: Manufacturer's name _____ Type Slots ☒ Ga. 8" Slot/gauze 1/8 Length 20' Set between 40 ft. and 60 ft. _____ ft. and _____ ft. Gravel pack? ☒ Size range of material 1/2"			
Soil				0		1		11. Static water level: _____ mo./day/yr. 32 ft. below land surface Date 6-20-79	
Red Clay				1		4		12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 40 g.p.m.	
White Clay				4		14		13. Water sample submitted: _____ mo./day/yr. Yes ☒ No ___ Date _____	
Buff Clay				14		30		14. Well head completion: ___ Pitless adapter _____ Inches above grade	
Gray Shale				30		38		15. Well grouted? yes With: ☒ Neat cement ___ Bentonite ___ Concrete ___ Depth: From 2 ft. to 19 ft.	
Buff Lime-water				38		45		16. Nearest source of possible contamination: ft. none Direction _____ Type _____ Well disinfected upon completion? ☒ Yes ___ No ___	
Buff Shale				45		50		17. Pump: ☒ Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: ___ Submersible ___ Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other	
Gray Shale				50		60		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Abraham & Plummer Business name Address Leon, Ks, 67074 License No. 181A Signed Jay Abraham Date 6-26-79 Authorized representative	
(Use a second sheet if needed)									
18. Elevation:		19. Remarks: Carney & Hall will install the 4x4 concrete slab.							
Topography: ___ Hill ___ Slope ☒ Upland ___ Valley									

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Certain-teed 8" P.V.C. -1120 SDR-26-160 BST (ASTM-D2241-NSF-PW-02FK 1M6)

MI-1023