


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>Sedgwick</u>	Fraction <u>1/4 NW 1/4 SW 1/4</u>	Section number <u>36</u>	Township number <u>T 28 S</u>	Range number <u>R 2 E</u>
2. Distance and direction from nearest town or city:		3. Owner of well:		6960 So. 143rd E.		
Street address of well location if in city: <u>Wichita, Kas.</u>		R.R. or street:		City, state, zip code: <u>Wichita, Kansas</u>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>4 1/2</u> in. Completion date: <u>8-13-76</u>		
				Well depth <u>75</u> ft.		
5. Type and color of material		From	To	7. ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug		
<u>Topsail</u>		<u>0</u>	<u>3</u>	☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary		
<u>Clay</u>		<u>3</u>	<u>15</u>	8. Use: ☒ Domestic ☐ Public supply ☐ Industry		
<u>Shale</u>		<u>15</u>	<u>75</u>	☐ Irrigation ☐ Air conditioning ☐ Stock		
				☐ Lawn ☐ Oil field water ☐ Other		
				9. Casing: Material <u>STYRENE</u> Height: <u>12</u> in.		
				Threaded ☐ Welded ☐ Surface ☐ RMP ☐ PVC ☐ Weight <u>15</u> lbs./ft.		
				Dia. <u>5</u> in. to <u>15</u> ft. depth Wall Thickness: inches or		
				Dia. <u>5</u> in. to <u>15</u> ft. depth Gauge No. <u>200</u>		
				10. Screen: Manufacturer's name <u>SUNFLOWER PLASTIC</u>		
				Type <u>STYRENE</u> Dia. <u>5"</u>		
				Slot gauge <u>1.86</u> Length <u>35 ft</u>		
				Set between <u>40</u> ft. and <u>75</u> ft.		
				Gravel pack? <u>YES</u> Size range of material <u>1/4-1/8"</u>		
				11. Static water level: <u>38</u> ft. below land surface Date <u>8-13-76</u>		
				12. Pumping level below land surfaces:		
				____ ft. after ____ hrs. pumping ____ g.p.m.		
				____ ft. after ____ hrs. pumping ____ g.p.m.		
				Estimated maximum yield ____ g.p.m.		
				13. Water sample submitted: ____ mo./day/yr.		
				☐ Yes ☐ No Date ____		
				14. Well head completion: <u>12</u> Capped		
				☐ Pitless adapter ____ inches above grade		
				15. Well grouted? <u>YES</u>		
				With: <u>Neat cement</u> ☐ Bentonite ☒ Concrete		
				Depth: From <u>40'</u> to <u>14</u> ft.		
				16. Nearest source of possible contamination: <u>30</u> ft. Direction <u>East</u> Type <u>Leak</u>		
				Well disinfected upon completion? ☒ Yes ☐ No		
				17. Pump: ☒ Not installed		
				Manufacturer's name ____		
				Model number ____ HP ____ Volts ____		
				Length of drop pipe ____ ft. capacity ____ g.p.m.		
				Type:		
				☐ Submersible ☐ Turbine		
				☐ Jet ☐ Reciprocating		
				☐ Centrifugal ☐ Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography:				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
☒ Hill				<u>HARP WELL & Pump 236</u>		
☐ Slope				Business name <u>WICHITA, KANSAS</u> License No. ____		
☐ Upland				Address <u>Wichita, Kansas</u>		
☐ Valley				Signed <u>M. Ornel</u> Date <u>8-19-76</u>		