

1 LOCATION OF WATER WELL:		Fraction	Section Number	Township Number	Range Number
County: <u>Butler</u>		<u>SE 1/4 NW 1/4 SW 1/4</u>	<u>35</u>	<u>T 28 S</u>	<u>R 3 EW</u>
Distance and direction from nearest town or city street address of well if located within city? <u>4 - East of Rose Hill Kan</u>					
2 WATER WELL OWNER:		Board of Agriculture, Division of Water Resources			
RR#, St. Address, Box # : <u>Lynn Hack Box 30</u>		Application Number:			
City, State, ZIP Code : <u>Rose Hill Kan 67002</u>					
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL <u>120</u> ft. ELEVATION:			
		Depth(s) Groundwater Encountered <u>1.100</u> ft. 2. ft. 3. ft.			
		WELL'S STATIC WATER LEVEL <u>45</u> ft. below land surface measured on mo/day/yr			
		Pump test data: Well water was ft. after hours pumping gpm			
		Est. Yield <u>50</u> gpm: Well water was ft. after hours pumping gpm			
		Bore Hole Diameter <u>9 1/2</u> in. to ft. and in. to ft.			
		WELL WATER TO BE USED AS:			
		☒ Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)			
		☐ 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well			
		Was a chemical/bacteriological sample submitted to Department? Yes No ☒ If yes, mo/day/yr sample was submitted			
		Water Well Disinfected? Yes ☒ No			
5 TYPE OF BLANK CASING USED:					
1 Steel		3 RMP (SR)		5 Wrought iron	
☒ 2 PVC		4 ABS		6 Asbestos-Cement	
				9 Other (specify below)	
				7 Fiberglass	
				CASING JOINTS: Glued ☒ Clamped	
Blank casing diameter <u>5</u> in. to <u>60</u> ft. Dia				Welded	
Casing height above land surface <u>18</u> in., weight <u>160</u> lbs./ft. Wall thickness or gauge No. <u>1214</u>				Threaded	
TYPE OF SCREEN OR PERFORATION MATERIAL:					
1 Steel		3 Stainless steel		5 Fiberglass	
2 Brass		4 Galvanized steel		6 Concrete tile	
				8 RMP (SR)	
				9 ABS	
				10 Asbestos-cement	
				11 Other (specify)	
				12 None used (open hole)	
SCREEN OR PERFORATION OPENINGS ARE:					
1 Continuous slot		3 Mill slot		5 Gauzed wrapped	
2 Louvered shutter		4 Key punched		6 Wire wrapped	
				7 Torch cut	
				8 Saw cut	
				9 Drilled holes	
				10 Other (specify)	
				11 None (open hole)	
SCREEN-PERFORATED INTERVALS: From <u>60</u> ft. to <u>120</u> ft. From ft. to ft.					
GRAVEL PACK INTERVALS: From ft. to ft. From ft. to ft.					
6 GROUT MATERIAL: 1 Neat cement 2 Cement grout ☒ 3 Bentonite 4 Other					
Grout Intervals: From <u>0</u> ft. to <u>23</u> ft. From ft. to ft. From ft. to ft.					
What is the nearest source of possible contamination:					
1 Septic tank		4 Lateral lines		7 Pit privy	
2 Sewer lines		5 Cess pool		☒ 8 Sewage lagoon	
3 Watertight sewer lines		6 Seepage pit		9 Feedyard	
10 Livestock pens		14 Abandoned water well		11 Fuel storage	
12 Fertilizer storage		16 Other (specify below)		13 Insecticide storage	
Direction from well? <u>East</u>		How many feet? <u>200</u>			
FROM TO		LITHOLOGIC LOG		FROM TO PLUGGING INTERVALS	
<u>0 3</u>		<u>Soil</u>			
<u>3 18</u>		<u>Clay</u>			
<u>18 120</u>		<u>Shale + lime</u>			
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was ☒ constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <u>4/26/97</u> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>257</u> This Water Well Record was completed on (mo/day/yr) <u>5/30/97</u> under the business name of <u>Winter Well Drill</u> by (signature) <u>Charles Winter</u>					