


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <i>Butler</i>	Fraction <i>NE 1/4 SW 1/4 SW 1/4</i>	Section number <i>23</i>	Township number T <i>28</i> S R <i>3E</i> E/W
2. Distance and direction from nearest town or city: <i>#5 North</i>		3. Owner of well: <i>Bob Miller</i>			
Street address of well location if in city:		R.R. or street: <i>R#1, Box 118</i>			
		City, state, zip code: <i>Douglas, Kansas</i>			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole (Dia. <i>11</i> in. Completion date <i>3-7-77</i>)	
		<i>4 miles East of the Rose Hill Rd and 47th St. So. Rose Hill, Kansas.</i>		Well depth <i>121</i> ft.	
5. Type and color of material		From	To	7. Cable tool ☒ Rotary ☐ Driven ☐ Dug	
<i>Topsoil</i>		<i>0</i>	<i>3</i>	☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary	
<i>Brown clay</i>		<i>3</i>	<i>10</i>	8. Use: ☒ Domestic ☐ Public supply ☐ Industry	
<i>Brown shale</i>		<i>10</i>	<i>30</i>	☐ Irrigation ☐ Air conditioning ☐ Stock	
<i>Gray shale</i>		<i>30</i>	<i>75</i>	☐ Lawn ☐ Oil field water ☐ Other	
<i>Brown shale</i>		<i>75</i>	<i>92</i>	9. Casing: Material <i>styrofoam</i> Height: above or below	
<i>Gray shale</i>		<i>92</i>	<i>117</i>	Threaded ☐ Welded ☒ Surface <i>12</i> in.	
<i>Limestone</i>		<i>117</i>	<i>121</i>	RMP ☒ PVC ☐ Weight <i>121</i> lbs./ft.	
				Dia. <i>5</i> in. to <i>121</i> ft. depth Wall Thickness: inches or	
				Dia. <i>5</i> in. to <i>121</i> ft. depth gauge No. <i>200</i>	
				10. Screen: Manufacturer's name <i>Sunflower plastic</i>	
				Type <i>styrene</i> Dia. <i>3</i> in.	
				Slot/gauze <i>.06</i> Length <i>18 ft</i>	
				Set between <i>93</i> ft. and <i>121</i> ft.	
				Gravel pack: <i>yes</i> Size range of material <i>14-18</i> in.	
				11. Static water level: <i>93</i> ft. below land surface Date <i>3-7-77</i>	
				12. Pumping level below land surfaces:	
				____ ft. after ____ hrs. pumping ____ g.p.m.	
				____ ft. after ____ hrs. pumping ____ g.p.m.	
				Estimated maximum yield ____ g.p.m.	
				13. Water sample submitted: ____ mo./day/yr.	
				____ Yes ____ No Date ____	
				14. Well head completion: <i>capped</i>	
				____ Pitless adapter <i>12</i> inches above grade	
				15. Well grouted <i>yes</i>	
				With: ____ Neat cement ____ Bentonite ☒ Concrete	
				Depth: From <i>40</i> in. to <i>14</i> ft. <i>OK</i>	
				16. Nearest source of possible contamination: <i>None</i>	
				ft. ____ Direction ____ Type ____	
				Well disinfected upon completion? ☒ Yes ____ No	
				17. Pump: ☒ Not installed	
				Manufacturer's name ____	
				Model number ____ HP ____ Volts ____	
				Length of drop pipe ____ ft. capacity ____ g.p.m.	
				Type: ____ Submersible ____ Turbine	
				____ Jet ____ Reciprocating	
				____ Centrifugal ____ Other	
18. Elevation:		19. Remarks:		20. Water well contractor's certification:	
Topography: ☐ Hill ☒ Slope ☐ Upland ☐ Valley		<i>Septic System not installed when the well was drilled. No apparent source for Contamination.</i>		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
				<i>Sharp Well Pump 236</i>	
				Business name <i>Wichita, Kansas</i> License No. ____	
				Address <i>M. Arnold</i> Date <i>3-22-77</i>	
				Signed <i>M. Arnold</i> Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5