

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Butler	Fraction 1/4 NW 1/4 NE 1/4	Section number 33	Township number T 28 S R 3E E/W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:	1 1/2 East of the Rose hill Road on 63 rd So.		3. Owner of well: Bill Hayden R #1 City, state, zip code: Rose Hill, Kansas		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile	Sketch map: Rose Hill, Kansas 		6. Bore hole dia. 11 in. Completion date 9-29-77 Well depth 70 ft.		
5. Type and color of material			7. ☒ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary		
			8. Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☐ Oil field water ☐ Other		
			9. Casing: Material styrene Height: Above or below Threaded ☐ Welded ☒ Surface 12 in. RMP ☒ PVC ☐ Weight ☐ lbs./ft. Dia. 5 in. to 70 ft. depth Wall Thickness: inches or Dia. ☐ in. to ☐ ft. depth gage No. 200		
			10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot/size .06 Length 50' Set between 20 ft. and 70 ft. ft. and ft. Gravel pack? yes Size range of material 1/4-1/8"		
			11. Static water level: 20 ft. below land surface Date 9-29-77 mo./day/yr.		
(Use a second sheet if needed)			12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
			13. Water sample submitted: mo./day/yr. Yes No Date		
			14. Well head completion: 12 capped Pitless adapter inches above grade		
			15. Well grouted? yes 1 -2 fine sand mix With: Neat cement Bentonite ☒ Concrete Depth: From 40" ft. to 14 ft.		
			16. Nearest source of possible contamination: Septic ft. 100 Direction SW Type Tank Well disinfected upon completion? ☒ Yes ☐ No		
(Use a second sheet if needed)			17. Pump: ☒ Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas Signed M. Arnold Date 12-10-77 Authorized representative		
			18. Elevation:		
			19. Remarks: Flat Ground		
			Topography: ☐ Hill ☐ Slope ☐ Upland ☐ Valley		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5