

1 LOCATION OF WATER WELL: Sedgwick	FRACTION NW 1/4 SW 1/4 NE 1/4	Section Number 5	Township Number T 29 S	Range Number R 1E E/W	
Distance and direction from nearest town or city street address of well if located within city? 71st St. S. & Marlen, 1/4 S. Haysville, Kansas					
WATER WELL OWNER: HAYSVILLE, CITY OF RR#, ST. ADDRESS, BOX #: 200 W. Grand CITY, STATE, ZIP CODE: Haysville, Kansas 67060 Board of Agriculture, Division of Water Resource Application Number: 20000215					
LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: 	4 DEPTH OF plugged WELL 40 ft. ELEVATION: Depth(s) groundwater Encountered 1 ft. 2 ft. 3 ft. WELL'S STATIC WATER LEVEL 10 FT. BELOW LAND SURFACE MEASURED ON 01/09/2001 Pump test data: Well water was ft. after hours pumping gpm Est. Yield gpm: Well water was ft. after hours pumping gpm Bore Hole Diameter in. to ft. and in. to ft. WELL WATER TO BE USED AS: 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well Was a chemical/bacteriological sample submitted to Department? Yes No ☒ ; If yes, mo/day/yr sample was submitted Water Well Disinfected? Yes ☒ No				
5 TYPE OF CASING USED: 1 Steel 3 RMP (SR) 2 PVC 4 ABS 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued Clamped 6 Asbestos-Cement 9 Other (Specify below) Welded 7 Fiberglass Threaded Blank casing Diameter 8 in. to ft. , Dia in. to ft. , Dia in. to ft. Casing height below land surface 36 in., weight lbs. / ft. Wall thickness or gauge No. TYPE OF SCREEN OR PERFORATION MATERIAL: 1 Steel 3 Stainless Steel 5 Fiberglass 8 RMP (SR) 11 other (specify) N/A 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole) SCREEN OR PERFORATION OPENING ARE: 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole) 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes 7 Torch cut 10 Other (specify) N/A SCREEN-PERFORATION INTERVALS: from ft. to ft. , From ft. to ft. from ft. to ft. , From ft. to ft. GRAVEL PACK INTERVALS: from ft. to ft. , From ft. to ft. from ft. to ft. , From ft. to ft.					
6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other bentonite hole plug Grout Intervals: From 3 ft. to 9 ft. From ft. to ft. From ft. to ft. From 9 ft. to 11 ft. What is the nearest source of possible contamination: 1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandon water well 2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well 3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below) 13 Insecticide storage None Apparent Direction from well? How many feet?					
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
			0	3	surface clay and silt
			3	9	cement grout
			9	11	bentonite hole plug
			11	40	chlorinated sand and gravel
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 01/09/01 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 236 This Water Well Record was completed on (mo/day/yr) 01/12/01 Under the business name of Harp Well & Pump Service, Inc. by (signature) Todd S. Harp					