

1 LOCATION OF WATER WELL:		Fraction	Section Number	Township Number	Range Number
County: <u>SEDGWICK</u>		<u>SE 1/4 NE 1/4 NE 1/4</u>	<u>30</u>	T <u>28</u> S <u>29</u>	R <u>1</u> E <u>2</u>
Distance and direction from nearest town or city street address of well if located within city? <u>1.5 N & 1.5 E of Park</u>					
2 WATER WELL OWNER: <u>Kent Ott</u>		#2 AEC			
RR#, St. Address, Box # : <u>103rd St. S. & Seneca</u>		Board of Agriculture, Division of Water Resources			
City, State, ZIP Code : <u>Park, KS</u>		Application Number:			
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL: <u>35</u> ft. ELEVATION:			
		Depth(s) Groundwater Encountered 1. <u>30.1</u> ft. 2. _____ ft. 3. _____ ft.			
		WELL'S STATIC WATER LEVEL <u>36.8</u> ft. below land surface measured on mo/day/yr <u>4-5-94</u>			
		Pump test data: Well water was _____ ft. after _____ hours pumping _____ gpm			
		Est. Yield _____ gpm: Well water was _____ ft. after _____ hours pumping _____ gpm			
		Bore Hole Diameter: <u>8</u> in. to <u>35</u> ft., and _____ in. to _____ ft.			
		WELL WATER TO BE USED AS:			
		5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well			
		Was a chemical/bacteriological sample submitted to Department? Yes <u>X</u> No _____; If yes, mo/day/yr sample was submitted <u>4-5-94</u>			
		Water Well Disinfected? Yes _____ No <u>X</u>			
5 TYPE OF BLANK CASING USED:					
1 Steel		5 Wrought iron		8 Concrete tile	
2 PVC		6 Asbestos-Cement		9 Other (specify below)	
3 RMP (SR)		7 Fiberglass		CASING JOINTS: Glued _____ Clamped _____	
4 ABS				Welded _____ Threaded <u>X</u>	
Blank casing diameter <u>2</u> in. to <u>25</u> ft., Dia. _____ in. to _____ ft., Dia. _____ in. to _____ ft.					
Casing height above land surface <u>36</u> in., weight <u>69</u> lbs./ft. Wall thickness or gauge No. _____					
TYPE OF SCREEN OR PERFORATION MATERIAL:					
1 Steel		3 Stainless steel		5 Fiberglass	
2 Brass		4 Galvanized steel		6 Concrete tile	
				8 RMP (SR)	
				9 ABS	
				10 Asbestos-cement	
				11 Other (specify) _____	
				12 None used (open hole)	
SCREEN OR PERFORATION OPENINGS ARE:					
1 Continuous slot		3 Mill slot		5 Gauzed wrapped	
2 Louvered shutter		4 Key punched		6 Wire wrapped	
				7 Torch cut	
				8 Saw cut	
				9 Drilled holes	
				10 Other (specify) _____	
				11 None (open hole)	
SCREEN-PERFORATED INTERVALS: From <u>25</u> ft. to <u>35</u> ft., From _____ ft. to _____ ft.					
GRAVEL PACK INTERVALS: From <u>23</u> ft. to <u>35</u> ft., From _____ ft. to _____ ft.					
6 GROUT MATERIAL: <u>1</u> Neat cement <u>1</u> Cement grout <u>3</u> Bentonite <u>4</u> Other _____					
Grout Intervals: From <u>0</u> ft. to <u>1</u> ft., From <u>1</u> ft. to <u>23</u> ft., From _____ ft. to _____ ft.					
What is the nearest source of possible contamination:					
1 Septic tank		4 Lateral lines		7 Pit privy	
2 Sewer lines		5 Cess pool		8 Sewage lagoon	
3 Watertight sewer lines		6 Seepage pit		9 Feedyard	
				10 Livestock pens	
				11 Fuel storage	
				12 Fertilizer storage	
				13 Insecticide storage	
				14 Abandoned water well	
				15 Oil well/Gas well	
				16 Other (specify below)	
Direction from well? _____ How many feet? _____					
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
<u>0</u>	<u>5</u>	<u>Topsoil</u>			
<u>5</u>	<u>15</u>	<u>Clay - brown, silty</u>			
<u>15</u>	<u>23</u>	<u>Silty sand, F-vfgn</u>			
<u>23</u>	<u>35</u>	<u>Sand - fine - CRSE</u>			
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was <u>(1)</u> constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <u>3-31-94</u> and this record is true to the best of my knowledge and belief, Kansas					
Water Well Contractor's License No. <u>102</u> This Water Well Record was completed on (mo/day/yr) <u>4-19-94</u>					
under the business name of <u>Layne, Inc.</u> by (signature) <u>Steven R. Mitchell</u>					

