


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

SE NE NE NW

1 Location of well:	County Sedgwick	Township name Salem	Fraction NW 1/4	Section number 1	Town number 29	Range number 1E	
Distance and direction from nearest town or city: in city of Derby, Ks			Owner of well: Everett Russell				
Street address of well location if in city: House faces Buckner at intersection of Harrell			Address: 7301 S 55 St E, Derby, Ks.				
Locate with "X" in section below: N  S W E			Sketch map:			4 Well depth: <u>80</u> ft. Date of completion <u>4-2-75</u> Well diameter <u>11</u> in.	
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
					6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
			Overburden sandy clay	0	25	7 Casing: Material RMP Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. 5" Weight 200 lbs./ft. sked 5 in. to 80 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No ___ in. to ___ ft. depth	
			clay lenses	25	60	8 Screen: Manufacturer J&L Type RMP Dia. 5" Slot/gauze .09375 Length 10' Set between 70 ft. and 80 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 3/8	
			shell	60	63	9 Static water level: 63 ft. below land surface Date 4-2-75	
			fine sand	63	70	10 Pumping level below land surfaces: 75 ft. after 1 hrs. pumping 4 g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield 4 g.p.m.	
			blue cracked soft shale	70	80	11 Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 4-15-75	
						12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> ___ Depth: From 10 ft. to GL ft.	
						14 Nearest source of possible contamination: ft. 25 Direction SE Type Wells Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
			15 Pump: customers <input type="checkbox"/> Not installed Manufacturer's name Burks Model number HUD HP 1 Volts 230 Length of drop pipe 75 ft. capacity 8 g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input checked="" type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
16 Remarks: elevation Approx 1365 MSL. Treated (20) abandoned pit wells, back-filled with clean treated sand, concrete Cap located 25' SE from new Well. Customer reports sample at pump near Well-head checks OK, still working to clear up Tank and house line Contam.			17 Water well contractor's certification: 135A This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Wilkinson Well Drilling 135 Business name License No. Address 1028 Ida, Wichita, Ks. Signed P.S. Wilkinson Date 6-4-75 Authorized representative				

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5