


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

|  |  |                           |  |                            |                                |                               |    |  |  |
|--|--|---------------------------|--|----------------------------|--------------------------------|-------------------------------|----|--|--|
| 1. Location of well:   |  | County<br><b>Sedgwick</b> | Fraction<br><b>X</b> Section   | Section number<br><b>1</b> | Township number<br><b>T 29</b> | Range number<br><b>S R 1E</b> |    |  |  |
| 2. Distance and direction from nearest town or city:<br><b>5001 East 71st St. So.</b><br>Street address of well location if in city: <b>Wichita, Kansas</b>  |  |                           | 3. Owner of well: <b>Larry Lusk</b><br>R.R. or street: <b>7224 Nelson Drive</b><br>City, state, zip code: <b>Derby, Kansas</b>   |                            |                                |                               |    |  |  |
| 4. Locate with "X" in section below:<br><div style="text-align: center;">  </div>   |  |                           | Sketch map:  |                            |                                |                               |    |  |  |
| 5. Type and color of material  |  |                           | From   | To                         |                                |                               |    |  |  |
|  |  |                           | Topsoil  |                            |                                | 0                             | 3  |  |  |
|  |  |                           | Clay   |                            |                                | 3                             | 18 |  |  |
|  |  |                           | Sandy Clay   |                            |                                | 18                            | 46 |  |  |
|  |  |                           | Medium Fine to Sand with Clay Streaks  |                            |                                | 46                            | 66 |  |  |
|  |  |                           | Blue Shale   |                            |                                | 66                            | 95 |  |  |
|  |  |                           |  |                            |                                |                               |    |  |  |
|  |  |                           |  |                            |                                |                               |    |  |  |
|  |  |                           |  |                            |                                |                               |    |  |  |
|  |  |                           |  |                            |                                |                               |    |  |  |
| 6. Bore hole dia. <b>11</b> in. Completion date <b>2-6-79</b><br>Well depth <b>95</b> ft.  |  |                           | 7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug<br><input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary   |                            |                                |                               |    |  |  |
| 8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry<br><input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock<br><input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other |  |                           | 9. Casing: Material <b>Styrene</b> Height: Above or below <b>111'</b><br>Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in.<br>RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft.<br>Dia. <b>5</b> in. to <b>95</b> ft. depth Wall Thickness: inches or<br>Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. <b>200</b>   |                            |                                |                               |    |  |  |
| 10. Screen: Manufacturer's name<br><b>Sunflower plastic</b><br>Type <b>styrene</b> Dia. <b>5"</b><br>Slot <b>1/16"</b> .06 Length <b>50'</b><br>Set between <b>45</b> ft. and <b>95</b> ft.<br>Set between <input type="checkbox"/> ft. and <input type="checkbox"/> ft.<br>Gravel pack? <b>yes</b> Size range of material <b>1/4-1/8"</b>             |  |                           | 11. Static water level: <input type="checkbox"/> mo./day/yr.<br><b>95</b> ft. below land surface Date <b>2-6-79</b>  |                            |                                |                               |    |  |  |
| 12. Pumping level below land surfaces:<br><input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m.<br><input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m.<br>Estimated maximum yield <input type="checkbox"/> g.p.m.                              |  |                           | 13. <input checked="" type="checkbox"/> Water sample submitted: <input type="checkbox"/> mo./day/yr.<br><input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>  |                            |                                |                               |    |  |  |
| 14. Well head completion: <b>12 capped</b><br><input type="checkbox"/> Pitless adapter <input type="checkbox"/> <b>12</b> Inches above grade   |  |                           | 15. Well grouted? <b>yes 1-2 fine sand mix</b><br>With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete<br>Depth: From <b>6</b> ft. to <b>16</b> ft.  |                            |                                |                               |    |  |  |
| 16. Nearest source of possible contamination: <b>NONE</b><br>ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/><br>Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No  |  |                           | 17. Pump: <input checked="" type="checkbox"/> Not installed<br>Manufacturer's name <input type="checkbox"/><br>Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/><br>Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m.<br>Type:<br><input type="checkbox"/> Submersible <input type="checkbox"/> Turbine<br><input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating<br><input type="checkbox"/> Centrifugal <input type="checkbox"/> Other |                            |                                |                               |    |  |  |
| 18. Elevation:   |  |                           | 20. Water well contractor's certification:<br>This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.<br><b>Harp Well &amp; Pump</b> <b>236</b><br>Business name <b>Wichita, Kansas</b> License No. <b>67209</b><br>Address <b>Derby, Kansas</b><br>Signed <b>M. Arnold</b> Date <b>2-6-79</b><br>Authorized representative  |                            |                                |                               |    |  |  |
| 19. Remarks:<br><b>Flat Ground</b><br><b>Septic System not installed at this time.</b><br><b>No apparent source for contamination.</b><br><b>Well is to be in the basement.</b>  |  |                           |  |                            |                                |                               |    |  |  |

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5