

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

|   |                                 |
|---|---------------------------------|
| 1. Location of well: County <u>Sedgwick</u> Fraction <u>SW 1/4 SE 1/4 SE 1/4</u> Section number <u>5</u> Township number <u>T 29 S</u> Range number <u>R 1 E</u>  |                                 |
| 2. Distance and direction from nearest town or city: <u>408 W. 79 St. So. Wichita, Kas.</u> 3. Owner of well: <u>Edward Miller</u> R.R. or street: <u>408 West 79th St. So.</u> City, state, zip code: <u>Wichita, Kansas</u>   |                                 |
| 4. Locate with "X" in section below: Sketch map:  |                                 |
| 6. Bore hole dia. <u>11</u> in. Completion date <u>10-15-75</u> Well depth <u>44</u> ft.  |                                 |
| 7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary  |                                 |
| 8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other  |                                 |
| 9. Casing: Material <u>stycor</u> Height <u>12</u> in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>1.950</u> lbs./ft. Dia. <u>5</u> in. to <u>44</u> ft. depth Wall Thickness: inches or Dia. <u>200</u> in. to <u>44</u> ft. depth gage No. <u>200</u>   |                                 |
| 5. Type and color of material   |                                 |
| <u>Sandy soil</u>   | From <u>0</u> To <u>2</u>       |
| <u>Sandy Clay</u>   | <u>2</u> <u>7</u>               |
| <u>Medium Sand</u>  | <u>7</u> <u>44</u>              |
| 10. Screen: Manufacturer's name <u>Sunflower Plastics</u> Type <u>Stycor</u> Dia. <u>5"</u> Slot/gauze <u>1.950</u> Length <u>20'</u> Set between <u>24</u> ft. and <u>44</u> ft. Gravel pack? <u>yes</u> size range of material <u>1/4-1/8"</u>  |                                 |
| 11. Static water level: <u>15</u> ft. below land surface Date <u>10-15-75</u> mo./day/yr.   |                                 |
| 12. Pumping level below land surfaces: <u>    </u> ft. after <u>    </u> hrs. pumping <u>    </u> g.p.m. Estimated maximum yield <u>    </u> g.p.m.   |                                 |
| 13. Water sample submitted: <u>    </u> Yes <u>    </u> No Date <u>    </u> mo./day/yr.   |                                 |
| 14. Well head completion: <u>12</u> <u>Capped</u> Pitless adapter <u>    </u> Inches above grade  |                                 |
| 15. Well grouted <u>yes</u> With: <u>    </u> Neat cement <u>    </u> Bentonite <u>    </u> Concrete Depth: From <u>40'</u> to <u>14</u> ft.  |                                 |
| 16. Nearest source of possible contamination: <u>100</u> ft. Direction <u>N. by</u> Type <u>Septic Tank</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No   |                                 |
| 17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u>    </u> Model number <u>    </u> HP <u>    </u> Volts <u>    </u> Length of drop pipe <u>    </u> ft. capacity <u>    </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other |                                 |
| (Use a second sheet if needed)  |                                 |
| 18. Elevation: <u>    </u> Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley   | 19. Remarks: <u>Flat Ground</u> |
| 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Harv Well Pump 236</u> Business name <u>Wichita, Kans.</u> License No. <u>    </u> Address <u>    </u> Signed <u>M. Arnold</u> Date <u>10-17-75</u> Authorized representative   |                                 |

T 29 S R 1 E  
Sec 5 SW SE SE  
1/4 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5