

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County: SEDGWICK	Fraction: 1/4 NW 1/4 NW 1/4	Section number: 8	Township number: T 29 S	Range number: R 1 E
2. Distance and direction from nearest town or city: 718 W. 81ST SO.			3. Owner of well: JOSEPH C. JACKSON		
Street address of well location if in city: WICHITA, KANSAS			R.R. or street: 718 W. 81ST SOUTH		
			City, state, zip code: WICHITA, KANSAS		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 10 in. Completion date 9-26-76	
				Well depth 45 ft.	
				7. ☒ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary	
				8. Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☐ Oil field water ☐ Other	
				9. Casing: Material STYRENE Height: above or below Threading: ☒ Welded ☒ GL Surface 12 in. RMP ☒ PVC ☐ Weight 10 lbs./ft. Dia. 5 in. to 45 ft. depth Wall Thickness: inches or Dia. 5 in. to 45 ft. depth Gage No. 200	
5. Type and color of material			From	To	10. Screen: Manufacturer's name SUNFLOWER PLASTIC
TOPSOIL			0	3	Type STYRENE Dia. 5"
FINE SAND			3	28	Slot gauge .06 Length 10'
MEDIUM SAND			28	45	Set between 35 ft. and 45 ft.
					Gravel pack? YES Size range of material 1/4-1/8
					11. Static water level: 15 ft. below land surface Date 9-26-76
					12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.
					13. Water sample submitted: ____ mo./day/yr. ____ Yes ____ No Date ____
					14. Well head completion: CAPPED ____ Pitless adapter 12 inches above grade
					15. Well grouted? YES With: ____ Neat cement ____ Bentonite ☒ Concrete Depth: From 40' to 14 ft.
					16. Nearest source of possible contamination: SEPTIC TANK ft. 50 Direction SW Type TANK Well disinfected upon completion? ☒ Yes ____ No
					17. Pump: ☒ Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other
			(Use a second sheet if needed)		
18. Elevation:	19. Remarks: FLAT GROUND		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. HARP WELL - Pump 236 Business name WICHITA, KANSAS License No. ____ Address WICHITA, KANSAS Signed M. Arnold Date 2-3-77 Authorized representative		
Topography: ____ Hill ____ Slope ____ Upland ____ Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5