

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County sedgwick	Fraction 1/4 nw 1/4 nw 1/4	Section number 9	Township number T 29 S R 1E E/W	Range number 1E
2. Distance and direction from nearest town or city: Street address of well location if in city: 1/2 mile east of Hydraulic on 95th St. South, on				3. Owner of well: Rodney Crabill R.R. or street: 705 East 79th So. City, state, zip code: Wichita, Kansas		
4. Locate with "X" in section below: Sketch map: the South Side of the Road . Wichita, Kansas				6. Bore hole dia. 11 in. Completion date _____ Well depth 40 ft. 3-30-78		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material				9. Casing: Material styrene Height: Above or below _____ Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. 5 in. to 40 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. .200		
				10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot/gauge .06 Length 15' Set between 25 ft. and 40 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 1/4-1/8"		
				11. Static water level: _____ mo./day/yr. 12 ft. below land surface Date 3-30-78		
				12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. Yes _____ No _____ Date _____		
				14. Well head completion: 12 capped <input type="checkbox"/> Pitless adapter _____ inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> yes 1-2 fine sand mix With: _____ Negt cement _____ Bentonite _____ Concrete _____ Depth: From 40 ft. to 14 ft.		
				16. Nearest source of possible contamination: NONE ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> X Yes _____ No _____		
				17. Pump: <input checked="" type="checkbox"/> X Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name: Wichita, Kansas License No. _____ Address _____ Signed M. Arnold Date 4-28-78 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Flat Ground Septic system not installed. No apparent source for contamination.				

T 29 S R 1E W Sec 9 NW 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5