

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

NE SE SE NW

1 Location of well:	County SEDEWICK	Township name SALEM	Fraction SW 1/4 SE 1/4	Section number 11	Town number T295	Range number R1E
Distance and direction from nearest town or city: 1/2 MI. WEST OF DERBY, KS.				3 Owner of well: CAMELOT CONSTRUCTION INC.		
Street address of well location if in city: 8320 HANCOCK DRIVE - DERBY KANS				Address: 706 N MAIN, WICHITA KANS 67202		
Locate with "X" in section below:		Sketch map:		4 Well depth: 15 ft. Date of completion 1-15-75 Well diameter 2 in.		
		<p>DRILLED 8" HOLE TO 4.5 FT. INSTALLED 4" CASING, GROUTED CASING.</p>		5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input checked="" type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
				7 Casing: Material AMP Height: BASEMENT above/below 7'00" ± Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 1/2 in. Diam. 30L Weight 155 lbs./ft. 4 in. to 5.5 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
2 Type and color of material		From To		8 Screen: Manufacturer MIDWEST Type BROSS Dia. 1.25 Slot gauze .060 Length 4 FT. Set between 11 ft. and 15 ft. Fittings CALV. IRON PIPE + COUPLING Gravel pack <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Size range of material ---		
MEDIUM SAND - TAN		0 4.5		9 Static water level: FROM BASEMENT FLOOR 4 ft. below land surface Date 1-15-75		
WATER BEARING SAND H²O		4 4.5		10 Pumping level below land surfaces: ___ ft. after ___ hrs. pumping NA g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield 40 g.p.m.		
DROVE 1.25 GALV. PIPE		4.5		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ---		
WITH POINT TO		15		12 Well head completion: 12" BASEMENT FLOOR <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade A		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 4.5 ft.		
				14 Nearest source of possible contamination: PLASTIC SEWER 10.5 Direction NE Type SEWER Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name ZFW Model number 7CPS HP 3/4 Volts 220 Length of drop pipe 15 ft. capacity 18 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input checked="" type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation 1300 FT.		(use a second sheet if needed)		17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. BEARDEN PUMP & WELL 104 Business name License No. Address 3142 MENTOR - WICHITA Signed OTIS W. BEARDEN date 2/26/76 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5