

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Sedgwick	Fraction NE NE 1/4 NE 1/4 NE 1/4	Section number 20	Township number T 29 S	Range number R 1E E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 9623 So. Broadway Wichita, Kansas		3. Owner of well: R.R. or street: Jack Ward 9623 South Broadway Wichita, Kansas City, state, zip code:			
4. Locate with "X" in section below: N W E S 1 Mile Sketch map: 		6. Bore hole dia. 11 in. Completion date 3-5-77 Well depth 40 ft.			
		7. ☒ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary			
		8. Use: ☐ Domestic ☐ Public supply ☐ Industry ☒ Irrigation ☐ Air conditioning ☐ Stock ☒ Lawn ☐ Oil field water ☐ Other			
		9. Casing: Material styrene Height: Above or below 11 Threading ☒ Welded gl Surface 12 in. RMP ☐ PVC ☐ Weight 10 lbs./ft. Dia. 5 in. to 40 ft. depth Wall Thickness: inches or Dia. 5 in. to 40 ft. depth gage No. .200			
5. Type and color of material		From	To		
Sandy Topsoil		0	2	10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5"	
Sandy Clay		2	8	Slot 1/4" Dia. .06 Length 10' Set between 30 ft. and 40 ft.	
Fine Sand		8	16	Gravel pack? yes Size range of material 1-1/8"	
Medium Sand		16	25	11. Static water level: 16 ft. below land surface Date 3-5-77 mo./day/yr.	
Coarse Sand		25	40	12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.	
				13. Water sample submitted: ____ mo./day/yr. Yes ____ No ____ Date ____	
				14. Well head completion: 12 capped Pitless adapter ____ inches above grade	
				15. Well grouted? yes With: ____ Neat cement ____ Bentonite ☒ Concrete Depth: From 40" to 14 ft.	
				16. Nearest source of possible contamination: Horse ft. 65 Direction West Type Lot Well disinfected upon completion? ☒ Yes ____ No	
				17. Pump: ☒ Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other	
		(Use a second sheet if needed)			
18. Elevation:	19. Remarks: Flat Ground		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Address Wichita, Kansas License No. ____ Signed M. Arnold Date 3-11-77 Authorized representative		
Topography: ____ Hill ____ Slope ____ Upland ____ Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5