

1 LOCATION OF WATER WELL:		Fraction: NW 1/4 NE 1/4 NE 1/4		Section Number: 7	Township Number: T 29S S		Range Number: R 2E E/W	
County: SEDGWICK								
Distance and direction from nearest town or city street address of well if located within city?								
307 S. BROOKFOREST; DERBY, KS								
2 WATER WELL OWNER: STEVE & PEGGY HUTSON								
RR#, St. Address, Box #: 307 S. BROOKFOREST								
City, State, ZIP Code: DERBY, KS								
Board of Agriculture, Division of Water Resources								
Application Number:								
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:			4 DEPTH OF COMPLETED WELL: 90 ft. ELEVATION:					
			Depth(s) Groundwater Encountered 1 22 ft. 2 ft. 3 ft.					
			WELL'S STATIC WATER LEVEL: 22 ft. below land surface measured on mo/day/yr 9-4-03					
			Pump-test data: Well-water was ft. after hours pumping gpm					
			Est. Yield gpm: Well-water was ft. after hours pumping gpm					
			Bore Hole Diameter 10 in. to 90 ft. and in. to ft.					
			WELL WATER TO BE USED AS: 5 Public water supply 8 Air conditioning 11 Injection well					
			1 Domestic 3 Feed lot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)					
			2 Irrigation 4 Industrial 7 Lawn and garden (domestic) 10 Monitoring well					
			Was a chemical/bacteriological sample submitted to Department? Yes No X If yes, mo/day/yr sample was submitted					
			Water Well Disinfected? Yes X No					
5 TYPE OF BLANK CASING USED:								
1 Steel			3 RMP (SR)			5 Wrought Iron		
2 PVC			4 ABS			6 Asbestos-Cement		
						7 Fiberglass		
Blank casing diameter 5 in. to 90 ft. Dia			in. to ft. Dia			in. to ft. Dia		
Casing height above land surface 16 in. weight 160 lbs./ft.			Wall thickness or gauge No. 26					
TYPE OF SCREEN OR PERFORATION MATERIAL:								
1 Steel			3 Stainless steel			5 Fiberglass		
2 Brass			4 Galvanized steel			6 Concrete tile		
SCREEN OR PERFORATION OPENINGS ARE:			5 Gauzed wrapped			8 Saw cut		
1 Continuous slot			3 Mill slot			6 Wire wrapped		
2 Louvered shutter			4 Key punched			7 Torch cut		
SCREEN-PERFORATED INTERVALS:			From 80 ft. to 90 ft.			From ft. to ft.		
GRAVEL PACK INTERVALS:			From 24 ft. to 90 ft.			From ft. to ft.		
6 GROUT MATERIAL:								
1 Neat cement			2 Cement grout			Bentonite		
Grout Intervals From 3 ft. to 24 ft.			ft. to ft. From ft. to ft.			ft. to ft.		
What is the nearest source of possible contamination:								
1 Septic tank			4 Lateral lines			7 Pit privy		
2 Sewer lines			5 Cess pool			8 Sewage lagoon		
3 Watertight sewer lines			6 Seepage pit			9 Feedyard		
						10 Livestock pens		
						11 Fuel storage		
						12 Fertilizer storage		
						13 Insecticide storage		
						14 Abandoned water well		
						15 Oil well/ Gas well		
						16 Other (specify below)		
Direction from well? SOUTH								
How many feet? 19								
FROM TO CODE LITHOLOGIC LOG FROM TO PLUGGING INTERVALS								
0 2 TOPSOIL								
2 22 CLAY								
22 26 FINE SAND								
26 38 BLUE SHALE								
38 56 LIMESTONE								
56 90 BLUE SHALE								
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/yr) 9-4-03 and this record is true to the best of my knowledge and belief. Kansas								
Water Well Contractor's License No. 611 This Water Well Record was completed on (mo/day/yr) 9-4-03								
under the business name of Chase Drilling by (signature) RICK CHASE								
INSTRUCTIONS: Please fill in blanks and circle the correct answers. Send three copies to Kansas Department of Health and Environment, Bureau of Water, 1000 S W Jackson St., Ste. 420, Topeka, Kansas 66612-1367. Telephone: 913-296-5545. Send one to WATER WELL OWNER and retain one for your records.								