

2	WATER WELL OWNER:	Tom Ingalls	
	RR#, St. Address, Box # :	718 Erin	Board of Agriculture, Division of Water Resources
	City, State, ZIP Code :	Mulvane, KS 67110	Application Number:

4 DEPTH OF COMPLETED WELL		30 ft. ELEVATION:		1252.22 (TOC)	
Depth(s) Groundwater Encountered		1 22.5	ft. 2	ft. 3	ft.
WELL'S STATIC WATER LEVEL		20.26 ft. below land surface measured on		mo/day/yr 9-22-05	
Pump test data:		Well water was	ft. after	hours pumping	gpm
Est. Yield		gpm: Well water was	ft. after	hours pumping	gpm
Bore Hole Diameter		8.5 in. to	30 ft. and	in. to	ft.
WELL WATER TO BE USED AS:		5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feed lot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden (domestic) 10 Monitoring well			
Was a chemical/bacteriological sample submitted to Department? Yes _____ No ☒ If yes, mo/day/yr sample was submitted					
Water Well Disinfected? Yes _____ No ☒					

5 TYPE OF BLANK CASING USED:		3 Wrought Iron	8 Concrete tile	CASING JOINTS: Glued _____ Clamped _____	
1 Steel	3 RMP (SR)	6 Asbestos-Cement	9 Other (specify below)	Welded _____	
2 PVC	4 ABS	7 Fiberglass		Threaded _____ Flush _____	
Blank casing diameter		2 in. to 15 ft., Dia	in. to _____ ft., Dia		in. to _____ ft.
Casing height above land surface		Flushmount	in., weight	0.703	lbs./ft. Wall thickness or gauge No. Sch. 40
TYPE OF SCREEN OR PERFORATION MATERIAL:					
1 Steel	3 Stainless steel	5 Fiberglass	7 PVC	10 Asbestos-cement	
2 Brass	4 Galvanized steel	6 Concrete tile	8 RMP (SR)	11 Other (specify) _____	
			9 ABS	12 None used (open hole)	
SCREEN OR PERFORATION OPENINGS ARE:					
1 Continuous slot	3 Mill slot	5 Gauzed wrapped	8 Saw cut	11 None (open hole)	
2 Louvered shutter	4 Key punched	6 Wire wrapped	9 Drilled holes		
			7 Torch cut	10 Other (specify) _____	
SCREEN-PERFORATED INTERVALS:					
From		15	ft. to	30	ft. From _____ ft. to _____ ft.
From			ft. to		ft. From _____ ft. to _____ ft.
GRAVEL PACK INTERVALS:					
From		13	ft. to	30	ft. From _____ ft. to _____ ft.
From			ft. to		ft. From _____ ft. to _____ ft.

6 GROUT MATERIAL:		1 Neat cement	2 Cement grout	3 Bentonite	4 Other
Grout Intervals		From 1 ft. to 13 ft.	From	ft. to	ft. From
What is the nearest source of possible contamination:					
1 Septic tank	4 Lateral lines	7 Pit privy	10 Livestock pens	14 Abandoned water well	
2 Sewer lines	5 Cess pool	8 Sewage lagoon	11 Fuel storage	15 Oil well/ Gas well	
3 Watertight sewer lines	6 Seepage pit	9 Feedyard	12 Fertilizer storage	16 Other (specify below)	
Direction from well?			How many feet?		

[illegible]

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/yr) 10-7-05 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 531 This Water Well Record was completed on (mo/day/yr) 10-11-05 under the business name of Geotechnical Services, Inc. by (signature) [Signature]

INSTRUCTIONS: Please fill in blanks and circle the correct answers. Send three copies to Kansas Department of Health and Environment, Bureau of Water, 1000 S W Jackson St., Ste. 420, Topeka, Kansas 66612-1367. Telephone: 913-296-5545. Send one to WATER WELL OWNER and retain one for your records.