

2	WATER WELL OWNER:	Tom Ingalls	
	RR#, St. Address, Box # :	718 Erin	Board of Agriculture, Division of Water Resources
	City, State, ZIP Code :	Mulvane, KS 67110	Application Number:

4 DEPTH OF COMPLETED WELL 30 ft. ELEVATION: 1249.89 (TOC)

Depth(s) Groundwater Encountered 1 19 ft. 2 _____ ft. 3 _____ ft.

WELL'S STATIC WATER LEVEL 18.4 ft. below land surface measured on mo/day/yr 9-22-05

Pump test data: Well water was _____ ft. after _____ hours pumping _____ gpm

Est. Yield _____ gpm: Well water was _____ ft. after _____ hours pumping _____ gpm

Bore Hole Diameter 8.5 in. to 30 ft. and _____ in. to _____ ft.

WELL WATER TO BE USED AS:

1 Domestic	3 Feed lot	5 Public water supply	8 Air conditioning	11 Injection well
2 Irrigation	4 Industrial	6 Oil field water supply	9 Dewatering	12 Other (Specify below)
		7 Lawn and garden (domestic)	10 Monitoring well	

Was a chemical/bacteriological sample submitted to Department? Yes _____ No **X** If yes, mo/day/yr sample was submitted _____

Water Well Disinfected? Yes _____ No **X**

5 TYPE OF BLANK CASING USED:		5 Wrought Iron	8 Concrete tile	CASING JOINTS: Glued _____ Clamped _____	
1 Steel	3 RMP (SR)	6 Asbestos-Cement	9 Other (specify below)	Welded _____	
2 PVC	4 ABS	7 Fiberglass	_____		Threaded _____ Flush _____
Blank casing diameter	2 in. to	15 ft. Dia	_____ in. to _____ ft. Dia	_____ in. to _____ ft.	

Casing height above land surface	Flushmount	in., weight	0.703	lbs./ft. Wall thickness or gauge No.	Sch. 40
TYPE OF SCREEN OR PERFORATION MATERIAL:			7 PVC	10 Asbestos-cement	
1 Steel	3 Stainless steel	5 Fiberglass	8 RMP (SR)	11 Other (specify)	
2 Brass	4 Galvanized steel	6 Concrete tile	9 ABS	12 None used (open hole)	
SCREEN OR PERFORATION OPENINGS ARE:			5 Gauzed wrapped	8 Saw cut	11 None (open hole)
1 Continuous slot	3 Mill slot	6 Wire wrapped	9 Drilled holes		
2 Louvered shutter	4 Key punched	7 Torch cut	10 Other (specify)		
SCREEN-PERFORATED INTERVALS:			From 15 ft. to 30 ft.	From	ft. to
			From	ft. to	ft.
GRAVEL PACK INTERVALS:			From 13 ft. to 30 ft.	From	ft. to
			From	ft. to	ft.

6 GROUT MATERIAL:		1 Neat cement	2 Cement grout	3 Bentonite	4 Other
Grout intervals		From 1 ft. to 13 ft.	From	ft. to	ft.
What is the nearest source of possible contamination:					
1 Septic tank	4 Lateral lines	7 Pit privy	10 Livestock pens	14 Abandoned water well	
2 Sewer lines	5 Cess pool	8 Sewage lagoon	11 Fuel storage	15 Oil well/ Gas well	
3 Watertight sewer lines	6 Seepage pit	9 Feedyard	12 Fertilizer storage	16 Other (specify below)	
Direction from well?			How many feet?		

[illegible]

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/yr) 10-7-05 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 531 This Water Well Record was completed on (mo/day/yr) 10-11-05 under the business name of Geotechnical Services, Inc. by (signature) [Signature]

INSTRUCTIONS: Please fill in blanks and circle the correct answers. Send three copies to Kansas Department of Health and Environment, Bureau of Water, 1000 S W Jackson St., Ste. 420, Topeka, Kansas 66612-1367. Telephone: 913-296-5545. Send one to WATER WELL OWNER and retain one for your records.