


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County SEDGWICK	Fraction 1/4 SW 1/4 SE 1/4	Section number 32	Township number T 29 S	Range number R 2E E/W
2. Distance and direction from nearest town or city: 3/4 S.E. of Rock Rd. on K-15, on the N. side of the road.		3. Owner of well: Darryl Starbird R.R. or street: 504 S.E. Lewis Blvd. City, state, zip code: Mulvane, Kansas			
4. Locate with "X" in section below: N Sketch map: Mulvane, Kansas W  E S 1 Mile		6. Bore hole dia. 11 in. Completion date _____ Well depth 60 ft. 6-5-78			
5. Type and color of material		7. ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary			
		8. Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☐ Oil field water ☐ Other			
		9. Casing: Material Styrene Height: Above or below _____ Threaded ☐ Welded ☒ Surface 12 in. RMP ☒ PVC _____ Weight _____ lbs./ft. Dia. 5 in. to 60 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. 200			
		10. Screen: Manufacturer's name _____ Sunflower Plastic Type styrene Dia. 5" Slot 1/16 Length 18' Set between 42 ft. and 60 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 1/4-1/8"			
		From	To	11. Static water level: _____ mo./day/yr. 31 ft. below land surface Date 6-5-78	
Topsoil		0	3	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
Clay		3	25	13. Water sample submitted: _____ mo./day/yr. Yes _____ No _____ Date _____	
Fine Sand		25	40	14. Well head completion: capped _____ Pitless adapter 12 inches above grade	
Gray Shale		40	60	15. Well grouted? yes 1-2 Fine Sand Mix With: _____ Neat cement _____ Bentonite ☒ Concrete Depth: From 40" ft. to 14 ft.	
				16. Nearest source of possible contamination: Septic ft. 60 Direction East Type Tank Well disinfected upon completion? ☒ Yes _____ No	
				17. Pump: ☒ Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other	
(Use a second sheet if needed)					
18. Elevation:	19. Remarks: Flat Ground		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas 67209 Signed M. Arnold Date 7-27-78 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5