

1 LOCATION OF WATER WELL		Fraction		Section Number		Township Number		Range Number					
County: BUTLER		SE 1/4 SW 1/4 SW 1/4		5		T 29 S		R 3 E EW					
Distance and direction from nearest town or city?				Street address of well if located within city? Rose Hill, Ks. 2710 Thistle Lane									
2 WATER WELL OWNER: Steven K. Schaffer													
RR#, St. Address, Box #: 2710 Thistle Lane						Board of Agriculture, Division of Water Resources							
City, State, ZIP Code: Rose Hill, Ks.						Application Number:							
3 DEPTH OF COMPLETED WELL: 7.2 ft. Bore Hole Diameter: 1.1 in. to ft. and in. to ft.													
Well Water to be used as:													
1 Domestic		3 Feedlot		5 Public water supply		8 Air conditioning		11 Injection well					
2 Irrigation		4 Industrial		6 Oil field water supply		9 Dewatering		12 Other (Specify below)					
				7 Lawn and garden only		10 Observation well							
Well's static water level: 1.5 ft. below land surface measured on 7 month 14 day 8.0 year													
Pump Test Data: Well water was ft. after hours pumping gpm													
Est. Yield gpm: Well water was ft. after hours pumping gpm													
4 TYPE OF BLANK CASING USED:													
1 Steel		3 RMP (SR)		5 Wrought iron		8 Concrete tile		Casing Joints: Glued X Clamped					
2 PVC		4 ABS		6 Asbestos-Cement		9 Other (specify below)		Welded					
				7 Fiberglass				Threaded					
Blank casing dia: 5 in. to 2.2 ft. Dia in. to ft. Dia in. to ft.													
Casing height above land surface: 1.2 in. weight lbs./ft. Wall thickness or gauge No. 2.00													
TYPE OF SCREEN OR PERFORATION MATERIAL:													
1 Steel		3 Stainless steel		5 Fiberglass		8 RMP (SR)		11 Other (specify)					
2 Brass		4 Galvanized steel		6 Concrete tile		9 ABS		12 None used (open hole)					
Screen or Perforation Openings Are:													
1 Continuous slot		3 Mill slot		5 Gauzed wrapped		8 Saw cut .06		11 None (open hole)					
2 Louvered shutter		4 Key punched		6 Wire wrapped		9 Drilled holes							
				7 Torch cut		10 Other (specify)							
Screen-Perforation Dia: 5 in. to 7.2 ft. Dia in. to ft. Dia in. to ft.													
Screen-Perforated Intervals: From 2.2 ft. to 7.2 ft. From ft. to ft. From ft. to ft.													
Gravel Pack Intervals: From 1.4 ft. to 7.2 ft. From ft. to ft. From ft. to ft.													
5 GROUT MATERIAL:													
1 Neat cement		2 Cement grout		3 Bentonite		4 Other							
Grouted Intervals: From 40 ft. to 1.4 ft. From ft. to ft. From ft. to ft.													
What is the nearest source of possible contamination:													
1 Septic tank		4 Cess pool		7 Sewage lagoon		10 Fuel storage		14 Abandoned water well					
2 Sewer lines		5 Seepage pit		8 Feed yard		11 Fertilizer storage		15 Oil well/Gas well					
3 Lateral lines		6 Pit privy		9 Livestock pens		12 Insecticide storage		16 Other (specify below)					
						13 Watertight sewer lines							
Direction from well: South How many feet: 7.8 ? Water Well Disinfected? Yes X No													
Was a chemical/bacteriological sample submitted to Department? Yes No X If yes, date sample was submitted month day year: Pump Installed? Yes No													
If Yes: Pump Manufacturer's name Model No. HP Volts													
Depth of Pump Intake ft. Pumps Capacity rated at gal./min.													
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other													
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on 7 month 14 day 8.0 year													
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 236													
This Water Well Record was completed on 9 month 30 day 1980 year under the business name of Harp Well & Pump by (signature) M. Arnold													
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:													
		FROM		TO		LITHOLOGIC LOG		FROM		TO		LITHOLOGIC LOG	
		0		3		Topsoil							
		3		12		Clay							
		12		41		Brown Shale							
		41		72		Grey Shale							
ELEVATION:													
Depth(s) Groundwater Encountered 1.43 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)													
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.													