


1 LOCATION OF WATER WELL: County: Butler		Fraction SE 1/4 SE 1/4 SE 1/4	Section Number 8	Township Number T 29 S	Range Number R 3 E
Distance and direction from nearest town or city street address of well if located within city? 1-5 - 1/2 - East of Rose Hill					
2 WATER WELL OWNER: RR#, St. Address, Box # : City, State, ZIP Code : Brad McCane Rose Hill 67183		Board of Agriculture, Division of Water Resources Application Number:			
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: 		4 DEPTH OF COMPLETED WELL: 94 ft. ELEVATION: 94 ft. Depth(s) Groundwater Encountered 1 ft. 2. ft. 3. ft. WELL'S STATIC WATER LEVEL 40 ft. below land surface measured on mo/day/yr Pump test data: Well water was ft. after hours pumping gpm Est. Yield 10 gpm: Well water was ft. after hours pumping gpm Bore Hole Diameter 8 1/2 in. to ft., and in. to ft. WELL WATER TO BE USED AS: 1 Domestic 2 Irrigation 3 Feedlot 4 Industrial 5 Public water supply 6 Oil field water supply 7 Lawn and garden only 8 Air conditioning 9 Dewatering 10 Monitoring well 11 Injection well 12 Other (Specify below) Was a chemical/bacteriological sample submitted to Department? Yes No X ; If yes, mo/day/yr sample was submitted Water Well Disinfected? Yes X No			
5 TYPE OF BLANK CASING USED: 1 Steel 2 PVC 3 RMP (SR) 4 ABS 5 Wrought iron 6 Asbestos-Cement 7 Fiberglass 8 Concrete tile 9 Other (specify below) Blank casing diameter 5 in. to 60 ft., Dia. in. to ft., Dia. in. to ft. Casing height above land surface 18 in., weight 160 lbs./ft. Wall thickness or gauge No. 12 1/4		CASING JOINTS: Glued X Clamped Welded Threaded			
TYPE OF SCREEN OR PERFORATION MATERIAL: 1 Steel 2 Brass 3 Stainless steel 4 Galvanized steel 5 Fiberglass 6 Concrete tile 7 PVC 8 RMP (SR) 9 ABS 10 Asbestos-cement 11 Other (specify) 12 None used (open hole) SCREEN OR PERFORATION OPENINGS ARE: 1 Continuous slot 2 Louvered shutter 3 Mill slot 4 Key punched 5 Gauzed wrapped 6 Wire wrapped 7 Torch cut 8 Saw cut 9 Drilled holes 10 Other (specify) 11 None (open hole)					
SCREEN-PERFORATED INTERVALS: From 60 ft. to 94 ft., From ft. to ft. From ft. to ft., From ft. to ft. GRAVEL PACK INTERVALS: From 60 ft. to 94 ft., From ft. to ft. From ft. to ft., From ft. to ft.					
6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other Grout Intervals: From 0 ft. to 20 ft., From ft. to ft., From ft. to ft. What is the nearest source of possible contamination: 1 Septic tank 2 Sewer lines 3 Watertight sewer lines 4 Lateral lines 5 Cess pool 6 Seepage pit 7 Pit privy 8 Sewage lagoon 9 Feedyard 10 Livestock pens 11 Fuel storage 12 Fertilizer storage 13 Insecticide storage 14 Abandoned water well 15 Oil well/Gas well 16 Other (specify below) Direction from well? S-East How many feet? 125					
FROM TO LITHOLOGIC LOG		FROM TO PLUGGING INTERVALS			
0 to 4 Spil 4 to 10 Clay 10 to 94 Shale + Lime					
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 12/24/90 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 251 This Water Well Record was completed on (mo/day/yr) 12/27/90 under the business name of Winter Well Drill by (signature) Charles Winter					