

ac

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

ABC  
WATER WELL RECORD  
KSA 82a-1201-1215  
SWNWNE

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Demaha</b>	Township name <b>Gilman</b>	Fraction <b>W 1/2 NE 1/4</b>	Section number <b>36</b>	Town number <b>2</b>	Range number <b>13</b>
Distance and direction from nearest town or city: <b>5 1/2 East Seneca, Ks.</b>			3 Owner of well: <b>Demaha County Sanitary Landfill</b>			
Locate with "X" in section below: N W E S 1 Mile			Sketch map: 650' 200'		4 Well depth: <b>60</b> ft. Date of completion <b>5/9/75</b> Well diameter <b>6</b> in.	
2 Well No <b>3</b>			Type and color of material	From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
			<b>Top Soil</b>	<b>0</b>	<b>1</b>	6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input checked="" type="checkbox"/> <b>Piez well</b>
			<b>Yellow Sandy Clay</b>	<b>1</b>	<b>12</b>	7 Casing: Material <b>PVC</b> Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <b>24</b> in. Diam. <b>4</b> in. to <b>60</b> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No — in. to — ft. depth
			<b>Gray Sandy Clay</b>	<b>12</b>	<b>21</b>	8 Screen: Manufacturer <b>CertaShield</b> Type <b>PVC</b> Dia. <b>4"</b> Slot/groove <b>.080</b> Length <b>20</b> Set between <b>40</b> ft. and <b>60</b> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <b>1/4 x 1/8</b>
			<b>Yellow Sandy Clay</b>	<b>21</b>	<b>35</b>	9 Static water level: <b>7.7'</b> ft. below land surface Date <b>5/13/75</b>
			<b>Gray Sandy Clay</b>	<b>35</b>	<b>60</b>	10 Pumping level below land surfaces: <b>NA</b> — ft. after — hrs. pumping — g.p.m. — ft. after — hrs. pumping — g.p.m. Estimated maximum yield — g.p.m.
						11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date —
						12 Well head completion: <b>Capped</b> <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <b>0</b> ft. to <b>10</b> ft.
						14 Nearest source of possible contamination: ft. <b>2000</b> Direction — Type <b>Barrenard</b> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No
						15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name — Model number — HP — Volts — Length of drop pipe — ft. capacity — g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
16 Remarks: elevation <b>122</b> Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Strader Drilling Co. Inc 182</b> Business Name License No. Address <b>Rt 1 Holton, Ks</b> Signed <b>Nancy Johnson</b> Date <b>6/3/75</b> Authorized representative

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5