

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

ACA
WATER WELL RECORD
KSA 82a-1201-1215

T	R	EW	sec	1/4	1/4	1/4	No.		

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Nemaha	Township name Gilman	Fraction W 1/4 NE 1/4	Section number 36	Town number 2	Range number 13
Distance and direction from nearest town or city: 5 1/2 East Seneca, Kansas			3 Owner of well: Nemaha County Sanitary Landfill Address: 111 Seneca, Kansas			
Street address of well location if in city:						
Locate with "X" in section below:						
2	Well No 5			Type and color of material	From	To
				Yellow Clay	0	10
				Gray Clay	10	30
				Yellow Clay	30	37
				Yellow Sandy Clay	37	49
				Gray Sandy Clay	49	60
16	Remarks: elevation 1310					
Topography:						
<input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						
4	Well depth: 60 ft. Date of completion 5/9/75 Well diameter 6 in.					
5	<input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary					
6	<input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input checked="" type="checkbox"/> Pizza Well					
7	Casing: Material PVC Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 42 in. Diam. 2 in. Weight 53 lbs./ft. 2 in. to 60 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to ft. depth					
8	Screen: Manufacturer Certainteed Type PVC Dia. 2" Slot/gauge .080 Length 20' Set between 30 ft. and 60 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 14x17					
9	Static water level: 21 1/2 ft. below land surface Date 5/13/75					
10	Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.					
11	Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date					
12	Well head completion: Capped <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade					
13	Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.					
14	Nearest source of possible contamination: ft. 2000 Direction SW Type Barney Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
15	Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
17	Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Strader Drilling Co., Inc. 182 Business name _____ License No. _____ Address 21 Holton, KS Signed Anna Johnson Date 6/3/75 Authorized representative					
(use a second sheet if needed)						

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5