

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

2 1 3 E 3 6 C S W N E

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:		County <u>Nebraska</u>	Township name <u>Galman</u>	Fraction <u>1 1/2 NE 1/4</u>	Section number <u>36</u>	Town number <u>2</u>	Range number <u>13</u>
Distance and direction from nearest town or city: <u>5 1/2 East Seneca, Kansas</u>				3 Owner of well: <u>Nebraska County Sanitary Landfill</u> Address: <u>500 S. Seneca, Kansas</u>			
Locate with "X" in section below:		Sketch map:		4 Well depth: <u>60</u> ft. Date of completion: <u>5/9/75</u> Well diameter <u>6</u> in.			
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input checked="" type="checkbox"/> <u>Pizz Well</u>			
				7 Casing: Material <u>PVC</u> Height: <u>above</u> below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>2 1/2</u> in. Diam. <u>2</u> in. to <u>60</u> ft. depth Weight <u>53</u> lbs./ft. Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
2 Well No <u>5</u>		Type and color of material		From	To	8 Screen:	
		<u>Yellow Clay</u>		<u>0</u>	<u>10</u>	Manufacturer <u>Certaincoat</u> Type <u>PVC</u> Dia. <u>2</u> "	
		<u>Gray Clay</u>		<u>10</u>	<u>30</u>	Slot/groove <u>.080</u> Length <u>20</u> "	
		<u>Yellow Clay</u>		<u>01</u>	<u>30</u>	Set between <u>40</u> ft. and <u>60</u> ft.	
		<u>Yellow Sandy Clay</u>		<u>37</u>	<u>49</u>	Fittings:	
		<u>Gray Sandy Clay</u>		<u>04</u>	<u>49</u>	Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>4x1/8</u>	
						9 Static water level: <u>21.6</u> ft. below land surface Date <u>5/13/75</u>	
						10 Pumping level below land surfaces: <u>N.A.</u> ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.	
						11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____	
						12 Well head completion: <u>Capped</u> <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> ____ Depth: From <u>0</u> ft. to <u>10</u> ft.	
						14 Nearest source of possible contamination: ft. <u>200</u> Direction <u>300</u> Type <u>300</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
						15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Stander Drilling Co. Inc</u> <u>182</u> Business name License No. Address <u>241 Holden St</u> Signed <u>Don Johnson</u> Date <u>6/3/75</u> Authorized representative			

