

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors)
Topeka, Kansas 66620

SW

1. Location of well:	County Brown	Fraction 1/4 SE 1/4 SE 1/4	Section number 22	Township number T 2 S	Range number R 16 E																					
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: STAN LOCK R.R. or street: R.R. City, state, zip code: Hiawatha, Kans. 66424																							
4. Locate with "X" in section below:			6. Bore hole dia. 10 in. Completion date Well depth 120 ft. 6-12-79																							
<p style="text-align: center;">Sketch map:</p>			7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary																							
5. Type and color of material			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other																							
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 80%;"></th> <th style="width: 10%;">From</th> <th style="width: 10%;">To</th> </tr> </thead> <tbody> <tr> <td>Top soil</td> <td>0</td> <td>9</td> </tr> <tr> <td>Clay, brown</td> <td>9</td> <td>28</td> </tr> <tr> <td>Fine sand - coarse sand - water bearing</td> <td>28</td> <td>30</td> </tr> <tr> <td>shale grey</td> <td>30</td> <td>85</td> </tr> <tr> <td>shaley lime</td> <td>85</td> <td>110</td> </tr> <tr> <td>shale grey</td> <td>110</td> <td>120</td> </tr> </tbody> </table>				From	To	Top soil	0	9	Clay, brown	9	28	Fine sand - coarse sand - water bearing	28	30	shale grey	30	85	shaley lime	85	110	shale grey	110	120	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 29 in. RMP <input type="checkbox"/> PVC 9L Weight 282 lbs./ft. Dia. 5 in. to 120 ft. depth, Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth, gage No. 1258		
				From	To																					
Top soil	0	9																								
Clay, brown	9	28																								
Fine sand - coarse sand - water bearing	28	30																								
shale grey	30	85																								
shaley lime	85	110																								
shale grey	110	120																								
			10. Screen: Manufacturer's name Pumpco Mat Type PVC Dia. 5 Slot gauze 1020 Length 20 Set between 20 ft. and 40 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1030/1060																							
			11. Static water level: <input type="checkbox"/> mo./day/yr. 25 ft. below land surface Date 6-12-79																							
			12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 3 g.p.m.																							
			13. Water sample submitted: ____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date																							
			14. Well head completion: CAP <input type="checkbox"/> Pitless adapter 24 inches above grade																							
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.																							
			16. Nearest source of possible contamination: ft. 200 Direction NW Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																							
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																							
18. Elevation: 1109 RM Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			19. Remarks: OWNET TO INSTALL SLAB																							
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STADER Drlg Co Inc 182 Business name _____ License No. _____ Address RT1 Holton KS Signed Dale Ashm Date 6-13-79 Authorized representative																							

T
 2
 16
 R
 W
 22
 SE
 SE
 SE
 SE
 1/4
 1/4
 1/4
 1/4
 Sec