

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Brown	Fraction NE 1/4 SE 1/4 SE 1/4	Section number 8	Township number T 2	Range number S 17	E/W
2. Distance and direction from nearest town or city: 2 miles north of Hiawatha, Kansas			3. Owner of well: Dan Hermesch			
Street address of well location if in city: now house			R.R. or street: 408 Shawnee			
			City, state, zip code: Hiawatha, Kansas 66434			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 42 in. Completion date 9-15-83		
				Well depth 70 ft. Bore hole 50' to 11'		
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material Concrete Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 28 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 320 lbs./ft. Dia. 36 in. to 70 ft. depth, Wall Thickness: inches or Dia. 36 in. to 70 ft. depth, gage No. 3 in.		
5. Type and color of material				10. Screen: Manufacturer's name _____		
				Type _____ Dia. _____ Slot/gauze _____ Length _____ Set between _____ ft. and _____ ft. _____ ft. and _____ ft. Gravel pack? _____ Size range of material _____		
Black top soil		From 0 To 1 1/2				
Yellow clay with rocks		1 1/2 20				
Same - some sand mixed in		20 36				
Dry yellow sand, mixed with clay		36 56				
Coarse sand and gravel with very large rocks - football size - very productive		56 70		11. Static water level: _____ mo./day/yr. 56 ft. below land surface Date 9-14-83		
Hard brown shale		70		12. Pumping level below land surfaces: 57 ft. after 6 hrs. pumping 30 g.p.m. 57 ft. after 14 hrs. pumping 30 g.p.m. Estimated maximum yield 30 g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
				14. Well head completion: _____ Pitless adapter _____ Inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 11 ft.		
				16. Nearest source of possible contamination: ft. 500 Direction S Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed. Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				18. Elevation: 1088		
19. Remarks:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Popplewell Well Boring 320 Business name Amity, Mo. 64422 license No. _____ Address _____ Signed Jerry Popplewell Date 9-23-83 Authorized representative		

83 to 11'
 2-17-83
 Sec 8-NESESE
 1/4 1/4 1/4