USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD KSA 82a-1201-1215

مرک

en

AAA

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)

	AAA				lopeka, Kansas 66620			
County			Section number		Township number	Range number]	
1. Location of well: Brown	NE 1/4 NE 1/4 NE	1/4		24	T 2 s	R 18		
2. Distance and direction from nearest town or city: 4		3. Owner	of wel	: Ha	rold Sommers	· · · · · · · · · · · · · · · · · · ·	1	
and 1 mile north of Highland, Kansas R.R. or : Street oddress of well location if in city:								
				ote, zip code: Robinson, Kansas 66532			7 6	
4. Locate with "A" in section below:	ketch map:		1	(Well depth 58 ft.	completion date 3/10/ pre hole is 42*	to 1	
	H045		1	8	7 Cable tool Rotary	Driven Dug	1	
NW NE			,	ř	Hollow rod Jetted	X Bored Reverse rotary	1	
w I I	700	7300	(ÿ	8. Use: _X Domestic P			
1				n l		ir conditioning Stock III field water Other	:	
sw se 2	Sa IV	> Mo	~	<i>κ</i>	9. Casing: Material CONC		1	
<u> </u>		X	<i>i</i> 4	U	Threaded Welded RMP PVC	Surface 200 lbs./ft.		
ı→ 1 Mile — →ı	HOG LOT L	1180			Dia in. to ft. dep			
5. Type and color of material			From	То	Dia.30 in. to 50 ft. dep	th gage No. 2 in.	1	
					10. Screen: Manufacturer's	name		
Black topsoil			0	2	Туре Даро	_ Dia		
Light Brown windblown			2	6	Slot/gauze	Lengthft. andft.		
D			`	3.7	ft.	andft.		
Brown windblown w/black st	reaks		6	17	Gravel pack? Size ro		1	
Grayish windblown			17	24	11. Static water level:36ft. below land su	mo./day/yr. rface Date <u>3/10/76</u>		
Brownish, fairly hard wind	blown		24	33	12. Pumping level below lan	d surfaces:		
Hand Vallow olay - yew hand			33	44	44 ft. after 2 51 ft. after 21			
Hard, Yellow clay - very hard					Estimated maximum yield —	15° 20° g.p.m.		
Fine to medium yellow sand that produces water			:44	49	13. Water sample submitted: YesX No	mo./day/yr. Date		
Coarse to very coarse sand	and gravel mix	ced	49	55	14. Well head completion:	Date	1	
with clay, very productive					Pitless adapter	Inches above grade	_	
and the second s		-+	p	0	15. Well grouted? X With: Neat cement	Bentonite Concrete		
Hard blue clay, very near shale			55	58	Depth: From ft. to		10	
					16. Nearest source of possible	SW Type Hog Lo		
					ft. 12) Direction Well disinfected upon complete		l .	
					17. Pump:	X Not installed		
					Manufacturer's name	HP Volts	10	
						ft. capacityg.p.m.	₹ @	
					Туре:	, , , -,		
					Submersible Jet	Turbine Reciprocating	IN	
(Use a second sh	eet if needed)				Centrifugal	Other	18,70	
18. Elevation: 19. Remarks: Concrete slab and vent will be instal Redval Well contractor's certification: 10. Concrete slab and vent will be instal Redval Well contractor's certification and this report. This well was drilled under my jurisdiction and this report.							1	
1069 by gustomer. He knows and understands this					is true to the best of my know	• • • • • • • • • • • • • • • • • • • •	>	
Topography: is a regulation. X Hill				POPPLEWELL WES	J. BORTNO 320	<u> </u>		
Slope				Address Amity	MO 64422 nse No.	512		
=Upland	Sommes!	,		•	Signed Drug Day	selvell Da 3/301	196m	
Valley	WITH THE				Authorized res	sentative	15/2	

Forward the white, blue and pink copies to the Department of Health and Environment

BR< 1011 = 1037