

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County DONIPHAN		Fraction NE 1/4 SE 1/4		Section number 23		Township number T 2		Range number S R 19		EW	
2. Distance and direction from nearest town or city: 1/2 MILE WEST, AND 1/2 MILE NORTH OF HIGHLAND, KANSAS Street address of well location if in city:					3. Owner of well: CONRAD CLARY R.R. or street: RR 1 City, state, zip code: HIGHLAND, KANSAS 66035						
4. Locate with "X" in section below: Sketch map:					6. Bore hole dia. <u>34</u> in. Completion date _____ Well depth <u>35</u> ft. FIRST 14' BORE IS 42" 9-25-75						
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary						
					8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other						
5. Type and color of material					9. Casing: Material <u>CONCRETE</u> Height: <u>30</u> in. above or below surface Threading: <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>30</u> in. RMP: <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>200</u> lbs./ft. Dia. <u>30</u> in. to <u>35</u> ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gauge No. <u>2 IN.</u>						
					10. Screen: Manufacturer's name _____ Type _____ Dia. _____ Slot/gauze _____ Length _____ Set between _____ ft. and _____ ft. _____ ft. and _____ ft. Gravel pack? <input type="checkbox"/> Size range of material _____						
TOPSOIL					11. Static water level: _____ mo./day/yr. <u>28</u> ft. below land surface Date <u>9-25-75</u>						
YELLOW FINE CLAY WINDBLOWN					12. Pumping level below land surfaces: <u>28</u> ft. after <u>1</u> hrs. pumping <u>7</u> g.p.m. <u>28</u> ft. after <u>3</u> hrs. pumping <u>9</u> g.p.m. Estimated maximum yield <u>11</u> g.p.m.						
GRAYISH CLAY, FAIRLEY LIGHT LIGHT YELLOW CLAY WITH STREAKS OF DARK DIRT					13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____						
YELLOW WIND BLOWN					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>30</u> Inches above grade						
COARSE YELLOW OR BROWN SAND WITH SOME 2" to 4"					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>3</u> ft. to <u>14</u> ft.						
GRAVEL - VERY WET					16. Nearest source of possible contamination: ft. <u>400</u> Direction <u>SW</u> Type <u>SEPTIC</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No						
BLUE SHALE - VERY HARD					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other						
(Use a second sheet if needed)					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. POPPELWELL WELL BORING 320 Business name _____ License No. _____ Address AMITY, MISSOURI Signed <u>Brody Poppe</u> <u>10/16/75</u> Date Authorized Representative						
18. Elevation: <u>950</u>		19. Remarks: CONCRETE SLAB AND VENT WILL BE INSTALLED BY CUSTOMER. HE KNOWS AND UNDERSTANDS THIS IS A REGULATION. <i>X Conrad R. Clary</i>									

42"
 T-2
 R-19
 W-23
 SE
 NE
 SE
 SE