

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County <u>Doniphan</u>		Fraction <u>SW 1/4 NW 1/4 NW 1/4</u>	Section number <u>24</u>	Township number <u>T 2 S</u>	Range number <u>R 19 E/W</u>
2. Distance and direction from nearest town or city: <u>1 E 3/4 N</u>		3. Owner of well: <u>Fred Kluk</u>		R.R. or street: <u>RR</u>	
Street address of well location if in city: <u>Highland</u>		City, state, zip code: <u>Highland</u>			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>8</u> in. Completion date <u>6-6-77</u>	
				Well depth <u>80</u> ft.	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material <u>PVC</u> Height <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>24</u> in. RMP <input type="checkbox"/> PVC <u>Blue</u> Weight <u>2.74</u> lbs./ft. Dia. <u>5</u> in. to <u>80</u> ft. depth; Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth; gage No. <u>255</u>	
5. Type and color of material		From	To	10. Screen: Manufacturer's name <u>Pumpco</u>	
<u>Top Soil</u>		<u>0</u>	<u>6</u>	Type <u>PVC</u> Dia. <u>5"</u>	
<u>Black loam</u>		<u>6</u>	<u>12</u>	Slot/gauze <u>.020</u> Length <u>15</u>	
<u>Brown Silty Clay</u>		<u>12</u>	<u>26</u>	Set between <u>25</u> ft. and <u>40</u> ft.	
<u>Brown Fine Sandy Clay</u>		<u>26</u>	<u>28</u>	ft. and <u> </u> ft.	
<u>Brown Rusty Coarse sandy Clay</u>		<u>28</u>	<u>34</u>	Gravel pack? <u>yes</u> Size range of material <u>0.30-0.80</u>	
<u>Gray Shale</u>		<u>34</u>	<u>49</u>	11. Static water level: <u>12</u> ft. below land surface Date <u>6-6-77</u>	
<u>Gray Limestone</u>		<u>49</u>	<u>52</u>	12. Pumping level below land surfaces: <u>Air Test</u>	
<u>Gray Shale</u>		<u>52</u>	<u>54</u>	<u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m.	
<u>Gray Limestone</u>		<u>54</u>	<u>55</u>	<u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m.	
<u>Gray Shale</u>		<u>55</u>	<u>57</u>	Estimated maximum yield <u>4</u> g.p.m.	
<u>Gray Limestone</u>		<u>57</u>	<u>59</u>	13. Water sample submitted: <u> </u> mo./day/yr.	
<u>Gray Shale</u>		<u>59</u>	<u>61</u>	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u> </u>	
<u>Gray Limestone</u>		<u>61</u>	<u>68</u>	14. Well head completion: <u>Cap Top</u>	
<u>Gray Shale</u>		<u>68</u>	<u>72</u>	<u> </u> Pitless adapter <u>24</u> Inches above grade	
<u>Gray Limestone</u>		<u>72</u>	<u>73</u>	15. Well grouted? <u>yes</u>	
<u>Gray Shale</u> (Use a second sheet if needed)		<u>73</u>	<u>80</u>	With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete	
18. Elevation: <u>915'</u>		19. Remarks: <u>Owner will construct cement slab around well</u>		Depth: From <u>0</u> ft. to <u>10</u> ft.	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley				16. Nearest source of possible contamination: ft. <u>400</u> Direction <u>North</u> Type <u>Lateral</u>	
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed	
				Manufacturer's name <u> </u>	
				Model number <u> </u> HP <u> </u> Volts <u> </u>	
				Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m.	
				Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
				Business name <u>Stanley Dale Co Inc</u> License No. <u>142</u>	
				Address <u>211 Walton, KS</u>	
				Signed <u>Dale Johnson</u> Date <u>6-7-77</u>	
				Authorized representative	

T-2
R-1220
W-24
SW NW NW
1/4 1/4 1/4