

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County WASHINGTON	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 9	Township number T 2 S R 3 E	Range number 3 E		
2. Distance and direction from nearest town or city: S N - 2 1/2 W			3. Owner of well: KENNETH APLEY					
Street address of well location if in city: WASHINGTON			R.R. or street: ROUTE 2					
			City, state, zip code: WASHINGTON, KANS 66968					
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date				
		<p>Well depth 100 ft. 2/10/77</p>		7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug				
				<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary				
<p>1 Mile</p> <p>1 Mile</p>		<p>1 Mile</p>		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry				
				<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				
5. Type and color of material		From		To		9. Casing: Material PVC Height: Above or below		
						Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 5.25 lbs./ft. Dia. 5 in. to 100 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1258		
TOPSOIL		0		2		10. Screen: Manufacturer's name PUMPEO		
GRAY CLAY		2		8		Type PVC Dia. 5		
BROWN CLAY		8		13		Slot gauze 1/16 " Length 20 '		
SANDY CLAY		13		23		Set between 80 ft. and 100 ft.		
RED CLAY		23		41		Gravel pack? <input checked="" type="checkbox"/> YES Size range of material 6/4		
GRAY CLAY		41		58		11. Static water level: 23 ft. below land surface Date 2/10/77		
RED CLAY		58		65		12. Pumping level below land surface:		
HARD ROCK		65		68		<input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 10 g.p.m.		
SANDROCK		68		100		13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date		
STOP		100				14. Well head completion:		
						<input checked="" type="checkbox"/> Pitless adapter 18 inches above grade		
						15. Well grouted? <input checked="" type="checkbox"/> YES		
						With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.		
						16. Nearest source of possible contamination: SEPTIC		
						ft. 75 Direction WEST Type TANK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
						17. Pump: <input checked="" type="checkbox"/> Not installed		
						Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:				
1390				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.				
Topography:				Geo Cox Sons Inc 358 Business name License No.				
<input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley				Address CUFTON KANSAS				
				Signed Daryl Cox Date 2/10/77 Authorized representative				

T
 2
 R
 3
 W
 E
 9
 SE SE SW
 1/4 1/4 1/4