


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County WASH	Township name FARMINGTON	Fraction NE 1/4	Section number 19	Town number T 2	Range number R 3 E
Distance and direction from nearest town or city: 2 NORTH Street address of well location if in city: 3 EAST OF MORROWVILLE				3 Owner of well: LAURENCE DILLER Address: MORROWVILLE		
Locate with "X" in section below: N 				Sketch map: WELL LOCATION		
2				4 Well depth: 162 ft. Date of completion 2/4/75 Well diameter 22 in.		
Type and color of material				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
TOPSOIL (BLACK) 0 3				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
CLAY (BROWN) 3 13				*7 Casing: Material PC Height above / Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. _____ Weight 30 lbs./ft. 12 in. to 162 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth		
SAND + GRAVEL (BROWN) 13 26				8 Screen: Manufacturer JOHNSON CONCRETE CO. Type SANDPAC Dia. 12 " Slot/gauze 1/8 " Length 39 " Set between 162 ft. and 123 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/2"		
CLAY (BROWN) 26 37				9 Static water level: 35 ft. below land surface Date 2/4/75		
SANDROCK (BROWN) 37 40				10 Pumping level below land surfaces: 160 ft. after 1 hrs. pumping 630 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 630 g.p.m.		
CLAY (GRAY) 40 67				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
SANDY CLAY (GRAY) 67 75				12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
SANDROCK (GRAY) 75 115				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 10 ft.		
CLAY (GRAY) 115 119				14 Nearest source of possible contamination: ft. 2000 Direction WEST Type CREEK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
SANDROCK (GRAY) 119 160				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
SHALE (GRAY) 160 162				16 Remarks: elevation 1390' Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		
STOPPED 162				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. GEO COX + SONS INC 258 Business name License No. _____ Address GLIETON KANS Signed Daryl Cox Date 2/11/75 Authorized representative		