

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Washington	Fraction SE 1/4 NW 1/4 SW 1/4	Section number 28	Township number T 2 S R 3 E W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:	2W - 2W - 1W 1/4 N of Washington		3. Owner of well: Raymond Willbrant R.R. no street #2 City, state, zip code: Washington, Ks 66968		
4. Locate with "X" in section below:	Sketch map:		6. Bore hole dia. 2 1/2 in. Completion date _____ Well depth 95 ft. 5-5-78		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material AC Height: Above or below _____ Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC _____ Weight 34 lbs./ft. Dia. 1 1/2 in. to 95 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 3/4	
top soil + clay		0	16	10. Screen: Manufacturer's name _____ Johnson Casey Co Type transite Dia. 1 1/2 Slot/gauge 1/8 Length 26 Set between 69 ft. and 95 ft. _____ ft. and _____ ft. Gravel pack? YES Size range of material 1/2-1/4	
sand + gravel		16	32	11. Static water level: _____ mo./day/yr. 20 ft. below land surface Date 5-3-78	
clay		32	36	12. Pumping level below land surfaces: 90 ft. after 1 hrs. pumping 300 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 300 g.p.m.	
sand rock		36	42	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
clay		42	46	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
sand rock + clay		46	51	15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
sand rock		51	89	16. Nearest source of possible contamination: NONE ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
clay + hard sand rock		89	103	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Cox-Beswick 361 Business name License No. Address Chilton, Kansas Signed Sharon Cox Date 5-27 Authorized representative		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

T-2
 R-3
 W-4
 Sec 28 SE 1/4 NW 1/4 SW 1/4