

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County WASHINGTON	Fraction NE 1/4 SE 1/4 NE 1/4	Section number 34	Township number T 2 S R 3 E W	Range number
2. Distance and direction from nearest town or city: 1 WEST 3/4 NORTH OF WASHINGTON.			3. Owner of well: WILLIS KEESECKER R.R. or street: RR City, state, zip code: WASHINGTON, KANS 66968		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 8 in. Completion date 12/3/75 Well depth 101 ft.
TOPSOIL			0	2	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
BROWN CLAY			2	22	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
SANDY CLAY			22	31	9. Casing: Material PVC Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft. Dia. 5 in. to 101 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 160 #
SANDROCK			31	40	10. Screen: Manufacturer's name CERTAINTEED Type PVC Dia. 5" Slot/gauze 1/16" Length 20' Set between 101 ft. and 81 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> YES Size range of material 1/4" x 1/8"
SANDROCK W/CLAY			40	64	11. Static water level: <input type="checkbox"/> mo./day/yr. 60 ft. below land surface Date 12/3/75
BROWN CLAY W/ROCK LAYERS			64	84	12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 25 g.p.m.
SANDROCK			84	101	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>
STOP			101		14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> <input type="checkbox"/> Inches above grade
					15. Well grouted? <input checked="" type="checkbox"/> YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: ft. 60 Direction Above type SEPTIC TANK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation: 1325	19. Remarks:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. BOB COX + SONS INC 258 Business name License No. Address CHATEAU, KANSAS Signed Boyd Cox Date 12/19/75 Authorized representative

T 2
R 3
W E
Sec 34
1/4 1/4 1/4
NE SE NE