


USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

X Location of well: <u>Marshall</u>		County <u>Marshall</u>	Fraction <u>SE 1/4 NW 1/4</u>	Section number <u>32</u>	Township number <u>3 South</u>	Range number <u>6 East</u>
X Distance and direction from nearest town or city: <u>1/4 mi South of Bremen 1/4 mi. E.</u>		3. Owner of well: <u>Lester B. Berman</u>		Street address of well location if in city: <u>Bremen Kansas</u>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>10</u> in. Completion date <u>2-5-77</u>		
				Well depth <u>59</u> ft.		
5. Type and color of material		From	To	7. X Cable tool <u>Rotary</u> <u>Driven</u> <u>Dug</u> <u>Hollow rod</u> <u>Jetted</u> <u>Bored</u> <u>Reverse rotary</u>		
<u>top soil Black</u>		<u>0</u>	<u>5</u>	8. Use: X Domestic <u>Public supply</u> <u>Industry</u> <u>Irrigation</u> <u>Air conditioning</u> <u>Stock</u> <u>Lawn</u> <u>Oil field water</u> <u>Other</u>		
<u>Clay Red</u>		<u>5</u>	<u>28</u>	X Casing: Material <u>PVC</u> Height <u>Above</u> or below Threaded <u>Welded</u> <u>Surface</u> <u>14</u> in. RMP <u>PVC</u> Weight <u>258</u> lbs./ft.		
<u>Rock yellow limestone</u>		<u>28</u>	<u>40</u>	Dia. <u>5</u> in. to <u>59</u> ft. depth Wall thickness <u>1/2</u> inches or Dia. <u>5</u> in. to <u>59</u> ft. depth gage No. <u>342 40</u>		
<u>Blue shale</u>		<u>40</u>	<u>59</u>	10. Screen: Manufacturer's name <u>AMP/pvc pumpco</u> Type <u>pvc</u> Dia. <u>5</u> Slot/gage <u>040</u> Length <u>30</u> Set between <u>29</u> ft. and <u>59</u> ft. ft. and <u>59</u> ft.		
				Gravel pack? X Size range of material <u>4X8</u>		
				11. Static water level: <u>35</u> ft. below land surface Date <u>2-5-77</u> mo./day/yr.		
				12. Pumping level below land surfaces: ft. after <u>40</u> hrs. pumping <u>40</u> g.p.m. ft. after <u>40</u> hrs. pumping <u>40</u> g.p.m. Estimated maximum yield <u>40</u> g.p.m.		
				13. Water sample submitted: <u>X</u> Yes <u>No</u> Date <u>NA</u> mo./day/yr.		
				14. Well head completion: <u>NA</u> <u>Pitless adapter</u> <u>Inches above grade</u>		
				15. Well grouted? X With: <u>Neat cement</u> <u>Bentonite</u> X <u>Concrete</u> Depth: From <u>5</u> ft. to <u>59</u> ft.		
				16. Nearest source of possible contamination: <u>100'</u> ft. Direction <u>east</u> Type <u>Lateral</u> Well disinfected upon completion? <u>Yes</u> <u>No</u>		
				17. Pump: X Not installed Manufacturer's name <u>Strader Drilling Co</u> Model number <u>Blue Raider</u> HP <u>2</u> Volts <u>115</u> Length of drop pipe <u>2</u> ft. capacity <u>2</u> g.p.m. Type: <u>Submersible</u> <u>Turbine</u> <u>Jet</u> <u>Reciprocating</u> <u>Centrifugal</u> <u>Other</u>		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Strader Drilling Co</u> License No. <u>1/31/74</u> Address <u>Harold Clark</u> Date <u>2-5-77</u> Signed <u>Harold Clark</u> Authorized representative		