

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Marshall	Fraction SE 1/4 NW 1/4 SW 1/4	Section number 8	Township number T 2 S	Range number R 8 E/W
2. Distance and direction from nearest town or city: 2-W-3 1/2-M. OF Home Kans. Street address of well location if in city:				3. Owner of well: Francis Taphorn R.R. or street: City, state, zip code: Home Ks. 66438		
4. Locate with "X" in section below: N W E S 1 Mile				Sketch map: 6. Bore hole dia. 8 in. Completion date Well depth 95 ft. OCT 12-79 7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material Pipe Height: Above ground Threaded <input type="checkbox"/> Welded Blue face 20 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 95 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. Sch 40 10. Screen: Manufacturer's name Pumpco Type PVC Dia. 5" Slot/gauze 1/16 65 Length 30 Set between 76 65 ft. and 95 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? Yes Size range of material 1/8-1/2 11. Static water level: <input type="checkbox"/> mo./day/yr. 60 ft. below land surface Date 10-12-79 12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m. 13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date 14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade 15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft. 16. Nearest source of possible contamination: Prairie ft. 75 Direction S Type Pitch Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No 17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
5. Type and color of material				From	To	
Clay Brown				0	15	
Sand Fine				15	25	
Clay Brown				25	45	
" Red				45	60	
Lime Rock White				60	65	
" " Yellow				65	70	
Clay " "				70	85	
" Brown				85	90	
Shale Blue				90	95	
(Use a second sheet if needed)						
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: Cement Slab To Be Poured by owner			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harpers Drilling Serv. 176 Business name License No. Address Blue Rapids Ks Signed G.E. Harpers 10-12-79 Authorized representative	