

1 LOCATION OF WATER WELL:		FRACTION		Section Number		Township Number		Range Number	
Sumner		NE 1/4 SW 1/4 SE 1/4		4		T 30 S		R 1E E/W	

Distance and direction from nearest town or city street address of well if located within city?

Lot 21, Wenzel Add., 3/4 m. S. of 119th S. & E. of turnpike

2	WATER WELL OWNER:	BANNON, Larry Construction		Board of Agriculture, Division of Water Resource
	RR#, ST. ADDRESS, BOX #:	1426 N. Broken Arrow Road		
	CITY, STATE, ZIP CODE:	Peck, Kansas	67120	
				Application Number:

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: <div style="text-align: center;"> </div>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">4 DEPTH OF COMPLETED WELL 30 ft.</td> <td style="width: 50%;">ELEVATION:</td> </tr> <tr> <td>Depth(s) groundwater Encountered 1 ft.</td> <td>2 ft.</td> </tr> <tr> <td colspan="2">WELL'S STATIC WATER LEVEL 15 FT. BELOW LAND SURFACE MEASURED ON 10/03/1995</td> </tr> <tr> <td>Pump test data:</td> <td>Well water was ft. after hours pumping gpm</td> </tr> <tr> <td>Est. Yield gpm:</td> <td>Well water was ft. after hours pumping gpm</td> </tr> <tr> <td>Bore Hole Diameter 12 in.</td> <td>to 30 ft. and in. to ft.</td> </tr> <tr> <td>WELL WATER TO BE USED AS:</td> <td> 5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well </td> </tr> <tr> <td colspan="2"> Was a chemical/bacteriological sample submitted to Department? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> ; If yes, mo/day/yr sample was submitted _____ </td> </tr> <tr> <td colspan="2"> Water Well Disinfected? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> </td> </tr> </table>	4 DEPTH OF COMPLETED WELL 30 ft.	ELEVATION:	Depth(s) groundwater Encountered 1 ft.	2 ft.	WELL'S STATIC WATER LEVEL 15 FT. BELOW LAND SURFACE MEASURED ON 10/03/1995		Pump test data:	Well water was ft. after hours pumping gpm	Est. Yield gpm:	Well water was ft. after hours pumping gpm	Bore Hole Diameter 12 in.	to 30 ft. and in. to ft.	WELL WATER TO BE USED AS:	5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well	Was a chemical/bacteriological sample submitted to Department? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> ; If yes, mo/day/yr sample was submitted _____		Water Well Disinfected? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
4 DEPTH OF COMPLETED WELL 30 ft.	ELEVATION:																		
Depth(s) groundwater Encountered 1 ft.	2 ft.																		
WELL'S STATIC WATER LEVEL 15 FT. BELOW LAND SURFACE MEASURED ON 10/03/1995																			
Pump test data:	Well water was ft. after hours pumping gpm																		
Est. Yield gpm:	Well water was ft. after hours pumping gpm																		
Bore Hole Diameter 12 in.	to 30 ft. and in. to ft.																		
WELL WATER TO BE USED AS:	5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well																		
Was a chemical/bacteriological sample submitted to Department? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> ; If yes, mo/day/yr sample was submitted _____																			
Water Well Disinfected? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>																			

5 TYPE OF CASING USED:		3 Wrought iron		8 Concrete tile		CASING JOINTS:		Glued <input checked="" type="checkbox"/> Clamped	
1 Steel		6 Asbestos-Cement		9 Other (Specify below)				Welded	
2 PVC		7 Fiberglass		SDR-26				Threaded	
Blank casing Diameter 5 in. to 24		ft., Dia		in. to		ft., Dia		in. to	
Casing height above land surface 12 in.		weight 2.35		lbs. / ft.		Wall thickness or gauge No.		.214	
TYPE OF SCREEN OR PERFORATION MATERIAL:		5 Fiberglass		7 PVC		10 Asbestos-cement			
1 Steel		3 Stainless Steel		8 RMP (SR)		11 other (specify)			
2 Brass		4 Galvanized steel		9 ABS		12 None used (open hole)			
SCREEN OR PERFORATION OPENING ARE:		5 Gauzed wrapped		8 Saw cut		11 None (open hole)			
1 Continuous slot		6 Wire wrapped		9 Drilled holes					
2 Louvered shutter		7 Torch cut		10 Other (specify)					
3 Mill slot									
4 Key punched									
SCREEN-PERFORATION INTERVALS:		from 24		ft. to 30		ft., From		ft. to	
		from		ft. to		ft., From		ft. to	
GRAVEL PACK INTERVALS:		from 24		ft. to 30		ft., From		ft. to	
		from		ft. to		ft., From		ft. to	

6	GROUT MATERIAL: 1 Neat cement		2 Cement grout		3 Bentonite		4 Other		
	Grout Intervals: From 4 ft. to 24 ft.		ft. From		ft. to		ft. From		
What is the nearest source of possible contamination:					10 Livestock pens		14 Abandon water well		
1 Septic tank		4 Lateral lines		7 Pit privy		11 Fuel storage		15 Oil well/Gas well	
2 Sewer lines		5 Cess pool		8 Sewage lagoon		12 Fertilizer storage		16 Other (specify below)	
3 Watertight sewer lines		6 Seepage pit		9 Feedyard		13 Insecticide storage		None Apparent	
Direction from well?					How many feet?				

[illegible]

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 10/03/1995 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 236 This Water Well Record was completed on (mo/day/yr) 10/05/95 Under the business name of Harp Well & Pump Service, Inc. by (signature) Jane Frederick