


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Sumner	Fraction 1/4 NE 1/4 NW 1/4	Section number 5	Township number T 30 S	Range number R 1E E/W										
2. Distance and direction from nearest town or city: Street address of well location if in city: 12121 South Broadway Mulvane, Kansas			3. Owner of well: Byron Nye Homes R.R. or street: Box 6 City, state, zip code: Mulvane, Kansas												
4. Locate with "X" in section below: <div style="text-align: center;">  </div>			Sketch map:												
5. Type and color of material			6. Bore hole dia. <u>11</u> in. Completion date <u>12-12-78</u> Well depth <u>45</u> ft.												
			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary												
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry</td> <td style="width: 50%;"></td> </tr> <tr> <td><input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock</td> <td></td> </tr> <tr> <td><input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other</td> <td></td> </tr> </table>			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry		<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock		<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		9. Casing: Material <u>Styrene</u> Height: Above or below <u>gl</u> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>12</u> lbs./ft. Dia. <u>5</u> in. to <u>45</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth Gauge No. <u>200</u>						
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry												
<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock															
<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other															
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">10. Screen: Manufacturer's name <u>Sunflower plastic</u></td> <td style="width: 50%;"></td> </tr> <tr> <td>Type <u>styrene</u> Dia. <u>5"</u></td> <td></td> </tr> <tr> <td>Slot/groove <u>.06</u> Length <u>15'</u></td> <td></td> </tr> <tr> <td>Set between <u>30</u> ft. and <u>45</u> ft.</td> <td></td> </tr> <tr> <td colspan="2">Gravel pack? <u>yes</u> Size range of material <u>1/4-1/8"</u></td> </tr> </table>			10. Screen: Manufacturer's name <u>Sunflower plastic</u>		Type <u>styrene</u> Dia. <u>5"</u>		Slot/groove <u>.06</u> Length <u>15'</u>		Set between <u>30</u> ft. and <u>45</u> ft.		Gravel pack? <u>yes</u> Size range of material <u>1/4-1/8"</u>		11. Static water level: <u>15</u> ft. below land surface Date <u>12-12-78</u> mo./day/yr.		
			10. Screen: Manufacturer's name <u>Sunflower plastic</u>												
Type <u>styrene</u> Dia. <u>5"</u>															
Slot/groove <u>.06</u> Length <u>15'</u>															
Set between <u>30</u> ft. and <u>45</u> ft.															
Gravel pack? <u>yes</u> Size range of material <u>1/4-1/8"</u>															
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">12. Pumping level below land surfaces:</td> <td style="width: 50%;"></td> </tr> <tr> <td><u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m.</td> <td></td> </tr> <tr> <td><u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m.</td> <td></td> </tr> <tr> <td colspan="2">Estimated maximum yield <u> </u> g.p.m.</td> </tr> </table>			12. Pumping level below land surfaces:		<u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m.		<u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m.		Estimated maximum yield <u> </u> g.p.m.		13. Water sample submitted: <u> </u> mo./day/yr. <u> </u> Yes <u> </u> No Date <u> </u>				
			12. Pumping level below land surfaces:												
<u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m.															
<u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m.															
Estimated maximum yield <u> </u> g.p.m.															
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">14. Well head completion: <u>12</u> capped</td> <td style="width: 50%;"></td> </tr> <tr> <td><u> </u> Pitless adapter <u> </u> inches above grade</td> <td></td> </tr> </table>			14. Well head completion: <u>12</u> capped		<u> </u> Pitless adapter <u> </u> inches above grade		15. Well grouted? <u>yes</u> <u>1-2</u> fine sand mix With: <u> </u> Neat cement <u> </u> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>40"</u> ft. to <u>14</u> ft.								
			14. Well head completion: <u>12</u> capped												
<u> </u> Pitless adapter <u> </u> inches above grade															
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">16. Nearest source of possible contamination:</td> <td style="width: 50%;"></td> </tr> <tr> <td>ft. <u>100</u> Direction <u>S.W.</u> Type <u>Septic</u></td> <td></td> </tr> <tr> <td colspan="2">Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <u>tank</u> No</td> </tr> </table>			16. Nearest source of possible contamination:		ft. <u>100</u> Direction <u>S.W.</u> Type <u>Septic</u>		Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <u>tank</u> No		17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other						
			16. Nearest source of possible contamination:												
ft. <u>100</u> Direction <u>S.W.</u> Type <u>Septic</u>															
Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <u>tank</u> No															
18. Elevation:			19. Remarks: Flat ground												
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas 67209 Signed <u>M. Arnold</u> Date <u>12-30-78</u> Authorized representative															

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5