

1 LOCATION OF WATER WELL Fraction Section Number Township Number Range Number
 County: ~~SEDGWICK~~ SUMNER NE 1/4 NE 1/4 SE 1/4 23 T 30 S R 1E EW XX
 Distance and direction from nearest town or city? Street address of well if located within city?
 2 1/2 Miles ~~No. 3~~ of 119th So. on West side of Belle Plaine Rd. Belle Plaine, Kansas


2 WATER WELL OWNER: Doyle Conner
 RR#, St. Address, Box # : R. R. #1 Board of Agriculture, Division of Water Resources
 City, State, ZIP Code : Belle Plaine, Kansas Application Number:

3 DEPTH OF COMPLETED WELL 40 ft. Bore Hole Diameter 11 in. to ft. and in. to ft.
 Well Water to be used as: 5 Public water supply 8 Air conditioning 11 Injection well
 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Observation well
 Well's static water level 15 ft. below land surface measured on 8 month 10 day 1979 year
 Pump Test Data : Well water was ft. after hours pumping gpm
 Est. Yield gpm: Well water was ft. after hours pumping gpm

4 TYPE OF BLANK CASING USED: 5 Wrought iron 8 Concrete tile Casing Joints: Glued X Clamped
 1 Steel 3 RMP (SR) 6 Asbestos-Cement 9 Other (specify below) Welded
 2 PVC 4 ABS 7 Fiberglass Threaded
 Blank casing dia 5 in. to 20 ft. Dia in. to ft. Dia in. to ft.
 Casing height above land surface 12 in., weight lbs./ft. Wall thickness or gauge No. 200
 TYPE OF SCREEN OR PERFORATION MATERIAL: 7 PVC 10 Asbestos-cement
 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify)
 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)
 Screen or Perforation Openings Are: 5 Gauzed wrapped 8 Saw cut .06 11 None (open hole)
 1 Continuous slot 3 Mill slot 6 Wire wrapped 9 Drilled holes
 2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify)
 Screen-Perforation Dia 5 in. to 40 ft. Dia in. to ft. Dia in. to ft.
 Screen-Perforated Intervals: From 20 ft. to 40 ft. From ft. to ft.
 Gravel Pack Intervals: From 14 ft. to 40 ft. From ft. to ft.

5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other
 Grouted Intervals: From 14" ft. to 40 ft. From ft. to ft. From ft. to ft.
 What is the nearest source of possible contamination: 10 Fuel storage 14 Abandoned water well
 1 Septic tank 4 Cess pool 7 Sewage lagoon 11 Fertilizer storage 15 Oil well/Gas well
 2 Sewer lines 5 Seepage pit 8 Feed yard 12 Insecticide storage 16 Other (specify below)
 3 Lateral lines 6 Pit privy 9 Livestock pens 13 Watertight sewer lines
 Direction from well Northwest How many feet 98 ? Water Well Disinfected? Yes X No
 Was a chemical/bacteriological sample submitted to Department? Yes No X If yes, date sample
 was submitted month day year: Pump Installed? Yes No X
 If Yes: Pump Manufacturer's name Model No. HP Volts
 Depth of Pump Intake ft. Pumps Capacity rated at gal./min.
 Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was
 completed on 8 month 10 day 1979 year
 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 236.
 This Water Well Record was completed on 11 month 21 day 1979 year under the business
 name of Harp Well & Pump Service, Inc. by (signature) *M. Arnold*

7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:

 FROM TO LITHOLOGIC LOG FROM TO LITHOLOGIC LOG
 0 3 Topsoil
 3 10 Clay
 10 16 Fine Sand
 16 32 Medium Sand
 32 40 Grey Shale
 ELEVATION:

Depth(s) Groundwater Encountered 1. 15 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.

OFFICE USE ONLY
 T
 R
 EW
 SEC
 NE 1/4
 NE 1/4
 SE 1/4