


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Sumner	Fraction 1/4 SE 1/4 SE 1/4	Section number 5	Township number T 30 S	Range number R 1E E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 12091 Crow Peck, Kansas			3. Owner of well: Phillip Jones R.R. or street: 12091 Crow City, state, zip code: Peck, Kansas		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		
5. Type and color of material			6. Bore hole dia. <u>11</u> in. Completion date <u>10-30-78</u> Well depth <u>45</u> ft.		
			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <u>Styrene</u> Height: Above or <u>below</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u> </u> lbs./ft. Dia. <u>5</u> in. to <u>45</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gauge No. <u>200</u>		
			10. Screen: Manufacturer's name <u>Sunflower plastic</u> Type <u>styrene</u> Dia. <u>5"</u> Slot/size <u>1/4"</u> .06 Length <u>15'</u> Set between <u>30</u> ft. and <u>45</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <u>yes</u> Size range of material <u>1/4-1/8"</u>		
			11. Static water level: <u>15</u> ft. below land surface Date <u>10-30-78</u> mo./day/yr.		
			12. Pumping level below land surfaces: <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u> </u> g.p.m.		
			13. Water sample submitted: <u> </u> mo./day/yr. <u> </u> Yes <u> </u> No Date <u> </u>		
			14. Well head completion: <u>12</u> capped <u> </u> Pitless adapter <u> </u> Inches above grade		
			15. Well grouted? <u>Yes 1-2 fine sand mix</u> With: <u> </u> Neat cement <u> </u> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>40"</u> ft. to <u>14</u> ft.		
			16. Nearest source of possible contamination: ft. <u>75</u> Direction <u>S.W.</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <u>tank</u> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <u> </u> Submersible <u> </u> Turbine <u> </u> Jet <u> </u> Reciprocating <u> </u> Centrifugal <u> </u> Other		
			(Use a second sheet if needed)		
18. Elevation: Topography: <u> </u> Hill <u> </u> Slope <u> </u> Upland <u> </u> Valley		19. Remarks: Flat ground			
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name <u>Wichita, Kansas</u> License No. <u>67209</u> Address <u> </u> Signed <u>M. Arnold</u> Date <u>12-4-78</u> Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5