


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Sumner	Fraction 1/4 NE 1/4 SE 1/4	Section number 5	Township number T 30 S R 1E E/W	Range number 1E E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: #32 Estate Lane Peck, Kansas				3. Owner of well: Galen Nett R.R. or street: 3374 South Oak City, state, zip code: Wichita, Kansas		
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile				Sketch map: 		
5. Type and color of material				From	To	6. Bore hole dia. 11 in. Completion date 11-29-77 Well depth 50 ft.
Sandy Soil				0	2	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Sandy Clay				2	15	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Fine Sand				15	20	9. Casing: Material styrene Height: Above or below 11 Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 50 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .200
Medium Sand				20	30	10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot/gauge .06 Length 10' Set between 40 ft. and 50 ft. ft. and 50 ft. Gravel pack? yes Size range of material 1/4-1/8"
Coarse Sand				30	50	11. Static water level: 15 ft. below land surface Date 11-29-77 11 mo./day/yr.
						12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.
						13. Water sample submitted: mo./day/yr. Yes No Date
						14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade
						15. Well grouted? yes 1-2 fine sand mix With: Neat cement Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40' ft. to 14 ft.
						16. Nearest source of possible contamination: Septic ft. 70 Direction West Type Tank Well disinfected upon completion? Yes No
						17. Pump: Not installed Manufacturer's name Sta-Rite Model number 20P4C02 HP 1/2 Volts 230 Length of drop pipe 37 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)						
18. Elevation:		19. Remarks: Flat Ground				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. Address Signed M. Arnold Date 12-31-77 Authorized representative				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5