


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County SUMNER	Fraction 1/4 NE 1/4 NW 1/4	Section number 5	Township number 6 30 S	Range number 1E E/W
2. Distance and direction from nearest town or city: #1937 Country Estates		Owner of well: NETCO- Galen Nett			
Street address of well location if in city: Peck, Kansas		R.R. or street: 3374 S. Oak			
		City, state, zip code: Wichita, Kansas			
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 11 in. Completion date 7-22-78 Well depth 55 ft.	
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Topsoil		0	3	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Clay		3	12	9. Casing: Material Styrene Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 81 lbs./ft. Dia. 5 in. to 55 ft. depth Wall Thickness: inches or Dia. 5 in. to 55 ft. depth Gauge No. .200	
Fine Sand		12	35	10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot .06 Length 10' Set between 45 ft. and 55 ft. ft. and ft. Gravel pack? yes Size range of material 1/4-1/8"	
Medium Sand		35	55	11. Static water level: 20 ft. below land surface Date 7-22-78 mo./day/yr.	
				12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.	
				13. Water sample submitted: Yes <input type="checkbox"/> No <input type="checkbox"/> Date	
				14. Well head completion: X Pitless adapter 12 Inches above grade	
				15. Well grouted? yes 1-2 Fine Sand Mix With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40" ft. to 14 ft.	
				16. Nearest source of possible contamination: Septic ft. 50 Direction S.E. Type Tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Sta-Rite Model number 20P4D02 HP 1/2 Volts 230 Length of drop pipe 40 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas 67209 Signed M. Arnold Date 7-16-78 Authorized representative	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Flat Ground			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5