

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County SUMNER		Fraction 1/4 NW 1/4 NW 4		Section number 6		Township number T 30 S R 1		Range number 1	
2. Distance and direction from nearest town or city: 1/4 mile east OR MERIDIAN ON PECK ROAD				3. Owner of well: DON BURRIS R.R. or street: 3200 W 119TH ST. SO. City, state, zip code: PECK, KANSAS					
4. Locate with "X" in section below: PECK, KANSAS				6. Bore hole dia. 11 in. Completion date 10-5-76 Well depth 57 ft.					
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary					
5. Type and color of material				From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
SANDY SOIL				0		1		9. Casing: Material STYRENE Weight: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft.	
CLAY				1		4		Dia. 5 in. to 57 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gage No. 1200	
FINE SAND				4		20		10. Screen: Manufacturer's name SUNFLOWER PLASTIC Type STYRENE Dia. 5" Slot gauge 1.06 Length 10' Set between 47 ft. and 57 ft.	
MEDIUM SAND				20		57		Gravel pack? <input checked="" type="checkbox"/> YES Size range of material 14-18"	
								11. Static water level: _____ mo./day/yr. 15 ft. below land surface Date 10-5-76	
								12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
								13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input type="checkbox"/> Date _____	
								14. Well head completion: CAPPED <input type="checkbox"/> Pitless adapter 12 Inches above grade	
								15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40' to 14 ft.	
								16. Nearest source of possible contamination: SEPTIC TANK ft. 50 Direction EAST Type TANK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
								17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)									
18. Elevation:		19. Remarks: FLAT GROUND				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. HARWELL Pump 236 Business name WICHITA, KANSAS Address WICHITA, KANSAS Signed M. Arnold Date 10-17-76 Authorized representative			

30' L - 10' W - 10' S
 1/4 1/4 1/4 1/4
 NW NE
 SW SE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5