

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Sumner Sedgwick	Fraction 1/4 SW 1/4 NW 1/4	Section number 11	Township number T 30 S R 1E E/W	Range number		
2. Distance and direction from nearest town or city: Street address of well location if in city: 1 1/2 South of the Mulvane Road on			3. Owner of well: Gerald Nies R.R. or street: RFD #1 City, state, zip code: Mulvane, Kansas					
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile			Sketch map: Hillside on the West side of the road Mulvane, Kansas			6. Bore hole dia. 11 in. Completion date _____ Well depth 42 ft. 1-15-77		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material styrene Above or below Threading <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 42 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 200			10. Screen: Manufacturer's name _____ Sunflower Plastics Type styrene Dia. 5" Slot size .06 Length 10' Set between 32 ft. and 42 ft. ft. and _____ ft.		
			From To			Gravel pack <input checked="" type="checkbox"/> Size range of material 1/4 - 1/8"		
			Topsoil (Sandy)			11. Static water level: _____ mo./day/yr. 15 ft. below land surface Date 1-15-77		
			Fine Sand			12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
Medium Sand			13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input type="checkbox"/> No Date _____					
Shale			14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> 12 capped					
			15. Well grouted? yes ok 1-1 sand mix With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40" ft. to 14 ft. <input checked="" type="checkbox"/>					
			16. Nearest source of possible contamination: ft. _____ Direction _____ Type NONE Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)								
18. Elevation:		19. Remarks: Flat Ground Septic System not installed when the well drilled. No apparent source for contamination.						
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas Signed M. Arnold Date 3-20-77 Authorized representative						

30 - 10
1/4 SW NW
Sec 10