


Sent 2-8-77 to L.I.

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well: <u>Sumner</u>		County: <u>Sumner</u>	Fraction: <u>1/4 SE 1/4 SW 1/4</u>	Section number: <u>4</u>	Township number: <u>T 30 S</u>	Range number: <u>R 2 E</u>	
2. Distance and direction from nearest town or city: <u>10323 E. 119 South Mulvane, Kans</u>			3. Owner of well: <u>Robert Hedinger R. R. 1 Mulvane, Kansas</u>				
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. <u>12 in.</u> Completion date <u>11-20-75</u> Well depth <u>50 ft.</u>			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material			From	To	8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
<u>Topsoil</u>			<u>0</u>	<u>2</u>	9. Casing: Material <u>PVC</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>30 in.</u> RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>2.87 lbs./ft.</u> Dia. <u>5 in.</u> to <u>50 ft.</u> depth Wall Thickness: inches or Dia. <u>in.</u> to <u>ft.</u> depth gage No. <u>265</u>		
<u>Clay</u>			<u>2</u>	<u>17</u>	10. Screen: Manufacturer's name <u>PVC-NSF Approval 200 PSI</u> Type <u>PVC-200 PSI</u> Dia. <u>5 in.</u> Slot/gauze <u>0.75</u> Length <u>30 ft.</u> Set between <u>30 ft.</u> and <u>50 ft.</u> <u>ft.</u> and <u>ft.</u> Gravel pack <u>yes</u> Size range of material <u> </u>		
<u>Blue shale</u>			<u>17</u>	<u>50</u>	11. Static water level: <u>25 ft.</u> below land surface Date <u>11-20-75</u> mo./day/yr.		
					12. Pumping level below land surfaces: <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u> </u> g.p.m.		
					13. Water sample submitted: <u> </u> mo./day/yr. Yes <input type="checkbox"/> No <input type="checkbox"/> Date <u> </u>		
					14. Well head completion: <u>30 Capped</u> <u> </u> Pitless adapter <u>30</u> inches above grade		
					15. Well grouted: <u>yes</u> With: <u> </u> Neat cement <u> </u> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>30</u> ft.		
					16. Nearest source of possible contamination: <u>None</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:			19. Remarks: <u>Septic system not installed at this time</u>			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Sharp Well + Pump 236</u> Business name <u> </u> License No. <u> </u> Address <u>Wichita, Kansas</u> Signed <u>M. Arnold</u> 11-21-75 Date Authorized representative	

30 T
- 20 W
- 4 SE SW
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5