


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Sumner	Fraction 1/4 NE/4 NE 1/4	Section number 15	Township number T 30 S R 2E E/W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city: 1/4 No. of K-15 & 127th E Mulvane, Kansas				3. Owner of well: Continental Real Estate Construction, Inc. R.R. or street: P.O. Box 18552 City, state, zip code: Wichita, Kansas 67218		
4. Locate with "X" in section below: Sketch map: 				6. Bore hole dia. 11 in. Completion date _____ Well depth 65 ft. 12-3-77		
5. Type and color of material				From	To	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
						8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Topsoil				0	2	9. Casing: Material styrene Weight: Above or below _____ Threaded _____ Welded gl Surface 12 in. RMP 5 pvc Weight _____ lbs./ft. Dia. _____ in. to _____ ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. .200
Sandy Clay				2	12	10. Screen: Manufacturer's name _____ Sunflower Plastic Type styrene Dia. 5" Slot/gauze .06 Length 35' Set between 30 ft. and 65 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> yes size range of material 1/2-1/8"
Brown Clay				12	26	11. Static water level: _____ mg./day/yr. 28 ft. below land surface Date 12-3-77
Soft Brown Sandstone				26	28	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.
Brown Clay				28	46	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input type="checkbox"/> No Date _____
Blue Shale				46	65	14. Well head completion: _____ capped <input type="checkbox"/> Pitless adapter 12 inches above grade
						15. Well grouted? <input checked="" type="checkbox"/> yes 1-2 fine sand mix With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40" ft. to 14 ft.
						16. Nearest source of possible contamination: NONE ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						(Use a second sheet if needed)
18. Elevation:	19. Remarks:		20. Water well contractor's certification:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	Flat Ground Septic tank not installed at this time. No apparent source for contamination.		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name _____ License No. _____ Address Wichita, Kansas Signed M. Arndt Date 12-31-77 Authorized representative			

T 30 S R 2E E/W Sec 15