



USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

| | | | | | | |
|---|--|---|--|--|---|--|
| 1. Location of well: | | County Cowley | Section NE 1/4 SE 1/4 | Section number 9 | Township number T 30 S R 3E E/W | Range number 3E |
| 2. Distance and direction from nearest town or city: 4 mi N; 1 m. E of 1/2 N of Udall | | | 3. Owner of well: C.H. Schambacher R.R. or street: R.R. #2 City, state, zip code: Udall, Kansas 67196 | | | |
| 4. Locate with "X" in section below: | | Sketch map: | | 6. Bore hole dia. 10 in. Completion date 7-29-77 Well depth 55 ft. | | |
|  | |  | | 7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary | | |
| 5. Type and color of material | | From | | To | | 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other |
| Top Soil | | 0 | | 5' | | 9. Casing: Material RMP Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 155 lbs./ft. Dia. 6 in. to 55 ft. depth Wall Thickness: inches or Dia. 6 in. to 55 ft. depth gage No. 250 |
| Red Clay | | 5' | | 12' | | 10. Screen: Manufacturer's name Sunflower Type RMP Dia. 6" Slot/gauze 1/16" Length 20' Set between 35 ft. and 55 ft. ft. and 55 ft. Gravel pack? Yes Size range of material 5/8" |
| Gray Schale | | 12' | | 38' | | 11. Static water level: 12 ft. below land surface Date 7-20-77 |
| Blue Schale | | 38' | | 41' | | 12. Pumping level below land surfaces: NA ft. after NA hrs. pumping NA g.p.m. ft. after NA hrs. pumping NA g.p.m. Estimated maximum yield NA g.p.m. |
| Hard Blue Schale | | 41' | | 55' | | 13. Water sample submitted: NA mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 7-20-77 |
| | | | | | | 14. Well head completion: NO <input type="checkbox"/> Pitless adapter NO Inches above grade |
| | | | | | | <input checked="" type="checkbox"/> Well grouted? NO With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From NA ft. to NA ft. |
| | | | | | | 16. Nearest source of possible contamination: ft. 400 Direction South Type Fuel Tank Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> |
| | | | | | | 17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name NA Model number NA HP NA Volts NA Length of drop pipe NA ft. capacity NA g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other |
| 18. Elevation: | | 19. Remarks: | | 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. EASTMAN Drilling 299 Business name Box 115, Winfield License No. NA Address Box 115, Winfield Signed Eak Eastman Date 8-15-77 Authorized representative | | |
| Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley | | Old well to be plugged by landowner To be grouted by Landowner | | | | |

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5