

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Cowley	Township name Omnia	Fraction NW 1/4 SE 1/4 NW 1/4	Section number 18	Town number 30 S	Range number 6 E
Distance and direction from nearest town or city: 3 miles west of Atlanta				3 Owner of well: Anna Wakefield 103 Massachusetts Winfield, Kansas 67156		
Locate with "X" in section below:		Sketch map:		4 Well depth: 90 ft. Date of completion 4-15-76 Well diameter 10 in.		
		5 <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
				7 Casing: Material RMP Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 20 in. Diam. 6 in. to 90 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No ___ in. to ___ ft. depth		
2 Type and color of material				From	To	8 Screen: Manufacturer Sunflower Type RMP Dia. 6" Slot/gauze .180 Length 20' Set between 70' ft. and 90' ft. Fittings: Gravel pack <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Size range of material 5/8
Top Soil & Red Clay				0	8	9 Static water level: 17 ft. below land surface Date 4-12-76
River bottom gravel up to 1 1/2 " dia				8	15	10 Pumping level below land surfaces: NA ft. after ___ hrs. pumping ___ g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield 3 g.p.m.
Cream colored limestone				15	23	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ___
Blue Shale				23	30	12 Well head completion: <input type="checkbox"/> Pitless adapter 20 inches above grade
Cream colored Limestone				30	34	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 12 ft.
Dark gray shale				34	51	14 Nearest source of possible contamination: ft. 150 Direction South Type hog Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Cream colored limestone				51	60	15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Myers Model number S2G31-3A 6 Volts 115 Length of drop pipe 80 ft. capacity 4.5 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Blue Shale				60	68	16 Remarks: elevation 17' to water level 4-12-76
Hard limestone				68	70	
Blue Shale				70	90	17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <i>Eastman Drilling 299</i> Business name Eastman Drilling 299 License No. 115 Address 207 115 Winfield Signed <i>Del Eastman</i> Date 4-27-76 Authorized representative
(use a second sheet if needed)						
16 Remarks: elevation 17' to water level 4-12-76						
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

30 6E 18 NWSE NR