


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County SUMNER	Fraction $\frac{1}{4}$ NW $\frac{1}{4}$ NW $\frac{1}{4}$	Section number 1	Township number T 31 S R	Range number 1E E/W
2. Distance and direction from nearest town or city: 1 block south of the hwy, Belle Plaine, Ks. Street address of well location if in city:				3. Owner of well: Doug Emerich R.R. or street: Box 711 City, state, zip code: Belle Plaine, Kansas		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 			6. Bore hole dia. $\frac{11}{40}$ in. Completion date: 3-20-79 Well depth _____ ft.	
5. Type and color of material		From	To	7. Cable tool <input checked="" type="checkbox"/> Rotary _____ Driven _____ Dug _____ Hollow rod _____ Jetted _____ Bored _____ Reverse rotary _____		
Topsoil		0	3	8. Use: _____ Domestic _____ Public supply _____ Industry _____ Irrigation _____ Air conditioning _____ Stock _____ <input checked="" type="checkbox"/> Lawn _____ Oil field water _____ Other _____		
Clay		3	10	9. Casing: Material styrene Height: Above or below 11/2 Threading _____ Welded _____ g Surface _____ 12 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. 5 in. to 40 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. .200		
Fine Sand		10	18	10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot/groove .06 Length 20' Set between 20 ft. and 40 ft. Set between _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Yes _____ No _____ range of material 1/4-1/8"		
Medium Sand		18	26	11. Static water level: _____ mo./day/yr. 15 ft. below land surface Date 3-20-79		
Grey Shale		26	40	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
				<input checked="" type="checkbox"/> Water sample submitted: _____ mo./day/yr. Yes _____ No _____ Date _____		
				14. Well head completion: _____ Pitless adapter 12 well seal _____ inches above grade		
				15. Well grouted yes 1-2 fine sand mix With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40 ft. to 14 ft.		
				16. Nearest source of possible contamination: Septic ft. 60 Direction North Type tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____		
				17. Pump: _____ Not installed Manufacturer's name Sta-Rite Model number 20 series $\frac{1}{2}$ hp Volts 230 Length of drop pipe 30 ft. capacity _____ g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other _____		
18. Elevation:		19. Remarks: Flat Ground		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. _____ Address _____ Signed M. Arnold Date 3-5-79 Authorized representative		
Topography: ____ Hill ____ Slope ____ Upland ____ Valley						

31-10-1-1
T
R
W
Sec
L
1
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5